

A Process Units

The steam networks, steam demand, aero-cooling and water-cooling demands of the units of Sites R and P are presented below. The steam properties are reconciled while the aero-cooling and water-cooling are not. All process data is also available online at [51].

The tables present steam demand, therefore negative values indicate a net import of steam while positive values correspond to what is imported by the Process Units (PUs) from the utility network. Similarly negative heat exchanges correspond to steam generation.

A.1 Site R Process Units

All process requirements are defined using True Boiling Point definitions shown in Tables A.7, A.8 and A.9. For injections, the pressure of the columns are given. This pressure can be used to calculate the minimum injection pressure of the steam.

Turbine isentropic efficiencies are also supplied so as to calculate the steam cogeneration. Their overview is presented in Table A.10.

Losses in the process units of Site R correspond to real physical losses as well as the remains of unexplained steam consumption.

Appendix A. Process Units

Unit A – Separation




Figure A.1 – Schematic of the steam network of Site R Unit A.

Table A.1 – Steam, cooling demand and mean thermodynamic properties for Site R Unit A.

Level [barg]	Type	Function	Flowrate [t/h]		Power [MW]		Process [°C]		Column [barg]	η [%]
			Mean	Max	Mean	Max	T_{in}	T_{out}		
20	Import		-10.8	-20.2	-6.2	-11.5				
20	Turbine	Turbo pumps	7.3	14.1	4.2	8.1				30.0
20	Stripping		2.5	4.0	1.4	2.3			9.0	
20	Losses		1.0	4.0	0.6	2.3				
	Total cons.		10.8	20.2	6.2	11.5				
5	HEX	Condensation	-5.3	-6.9	-3.2	-4.2	220	205		
5	Export		4.1	10.4	2.5	6.3				
5	HEX	Heating	5.0	16.9	3.0	10.2	110	150		
5	Injection	Storage tanks	0.9	1.2	0.5	0.7			0.4	
5	Tracing		2.0	2.7	1.2	1.6	90	105		
5	Losses		0.5	0.7	0.3	0.4				
	Total cons.		12.6	20.6	7.6	12.4				
	Aero cooling	Cooling			19.1	28.7	150	110		
	Water cooling	Cooling			5.3	8.1	100	60		

Unit B – Isomerisation




Figure A.2 – Schematic of the steam network of Site R Unit B.

Table A.2 – Steam, cooling demand and mean thermodynamic properties for Site R Unit B.

Level [barg]	Type	Function	Flowrate [t/h]		Power [MW]		Process [°C]		Column [barg]	η [%]
			Mean	Max	Mean	Max	T_{in}	T_{out}		
20	Import		-10.2	-16.5	-5.8	-9.4				
20	HEX	Evaporation	6.2	11.5	3.6	6.6	170	190	5.2	
20	Injection		1.2	1.5	0.7	0.9				
20	Letdown	2.0	5.7	1.2	3.3					
20	Losses		0.8	1.2	0.5	0.7				
Total cons.			10.2	16.5	5.8	9.4				
5	HEX	Cooling	-5.1	-6.3	-3.1	-3.8	210	187		
5	HEX	Evaporation	5.7	9.6	3.5	5.8	115	125		
5	Losses		0.5	0.5	0.3	0.3				
5	Tracing	Pipe tracing	0.9	1.0	0.5	0.6	90	105		
Total cons.			7.1	11.0	4.3	6.6				
	Aero cooling	Cooling			7.3	10.8	150	110		
	Water cooling	Cooling			5.4	7.8	100	60		

Unit C - Hydrogenation

Comments: Turbines used to compress gases. Reactors produce superheated steam.




Figure A.3 – Schematic of the steam network of Site R Unit C.

Table A.3 – Steam, cooling demand and mean thermodynamic properties for Site R Unit C.

Level [barg]	Type	Function	Flowrate [t/h]		Power [MW]		Process [°C]		Column [barg]	η [%]
			Mean	Max	Mean	Max	T_{in}	T_{out}		
90	Import		-13.4	-22.7	-7.3	-12.4				
90	HEX	Reactor cooling	-8.5	-14.3	-4.7	-7.8	550	500		
90	Turbine T1		9.1	18.8	5.0	10.3				40.0
90	Turbine T2		11.9	14.5	6.5	7.9				40.0
90	Letdown L1		1.0	2.1	0.5	1.1				
	Total cons.		21.9	31.4	12.0	17.2				
20	Import		-8.9	-19.3	-5.1	-11.1				
20	HEX		-6.0	-31.5	-3.5	-18.0	600	600		
20	HEX	Heating	21.2	31.9	12.1	18.2	150	200		
20	Losses		0.9	1.3	0.5	0.7	375	375		
20	Letdown L2		2.9	17.9	1.6	10.2				
	Total cons.		25.0	36.3	14.3	20.7				
5	HEX	Cooling	-7.5	-20.7	-4.5	-12.5	350	300		
5	Export		12.9	28.3	7.8	17.1				
5	HEX	Condensation	3.7	28.3	2.2	17.1	75	115		
5	Injection		2.0	2.8	1.2	1.7			1.0	
5	Losses		1.2	1.7	0.7	1.1				
5	Tracing		2.5	4.0	1.5	2.4	90	105		
	Total cons.		22.3	36.1	13.4	21.8				
	Aero cooling	Cooling			15.0	22.5	140	85		
	Water cooling	Cooling			8.8	18.4	125	65		

Appendix A. Process Units

Unit D - Cracker

Comments: Turbines used for turbo pumps. Reactors produce superheated steam.




Figure A.4 – Schematic of the steam network of Site R Unit D.

Table A.4 – Steam, cooling demand and mean thermodynamic properties for Site R Unit D.

Level [barg]	Type	Function	Flowrate [t/h]		Power [MW]		Process [°C]		Column [barg]	η [%]
			Mean	Max	Mean	Max	T_{in}	T_{out}		
90	Export		-12.8	-20.4	-7.0	-11.1				
90	HEX	Catalyser cooling	12.8	20.4	7.0	11.1	615	615		
	Total cons.		12.8	20.4	7.0	11.1				
20	Import		-7.5	-18.0	-4.3	-10.3				
20	HEX	Condensation	-10.1	-12.2	-5.8	-7.0	315	290		
20	HEX	Heating	16.1	29.5	9.2	16.9	125	180		
20	Losses		0.5	0.6	0.3	0.3				
20	Turbine		0.9	8.8	0.5	5.0				30.0
	Total cons.		17.6	30.0	10.0	17.2				
5	Import		-8.2	-18.6	-4.9	-11.2				
5	HEX	Condensation	-4.9	-18.6	-3.0	-11.2	204	197		
5	HEX	Evaporation	8.2	28.9	4.9	17.4	125	125		
5	Injection		1.4	2.2	0.8	1.3			1.5	
5	Letdown		1.9	3.4	1.1	2.1				
5	Losses		0.4	0.7	0.2	0.4				
5	Tracing	Tank heating	2.1	3.6	1.3	2.2	90	105		
	Total cons.		14.0	34.9	8.4	21.1				
2	HEX	Condensation	-1.4	-2.3	-0.9	-1.5	180	180		
2	Injection		0.8	1.5	0.5	0.9			-0.6	
2	Tracing	Pipe tracing	2.5	4.3	1.6	2.7	60	85		
	Total cons.		3.3	5.3	2.1	3.3				
	Aero cooling	Cooling			6.2	15.8	180	80		
	Water cooling	Cooling			9.0	26.2	130	65		

Appendix A. Process Units

Unit E - Separation




Figure A.5 – Schematic of the steam network of Site R Unit E.

Table A.5 – Steam, cooling demand and mean thermodynamic properties for Site R Unit E.

Level [barg]	Type	Function	Flowrate [t/h]		Power [MW]		Process [°C]		Column [barg]	η [%]
			Mean	Max	Mean	Max	T_{in}	T_{out}		
20	Import		-19.7	-27.7	-11.3	-15.9				
20	HEX	Evaporation	5.8	7.8	3.3	4.5	160	190		
20	HEX	Heating	13.2	21.4	7.5	12.3	120	170		
20	Losses		0.8	1.2	0.4	0.7				
	Total cons.		19.7	27.7	11.3	15.9				
5	Import		-13.4	-19.5	-8.1	-11.8				
5	HEX	Evaporation	4.0	5.3	2.4	3.2	115	115		
5	HEX	Heating	8.6	14.9	5.2	9.0	90	100		
5	Losses		0.7	1.5	0.4	0.9				
	Total cons.		13.4	19.5	8.1	11.8				
	Aero cooling	Cooling			3.8	5.2	150	95		
	Water cooling	Cooling			7.2	14.9	110	65		

Unit F - Purification




Figure A.6 – Schematic of the steam network of Site R Unit F.

Table A.6 – Steam, cooling demand and mean thermodynamic properties for Site R Unit F.

Level [barg]	Type	Function	Flowrate [t/h]		Power [MW]		Process [°C]		Column [barg]	η [%]
			Mean	Max	Mean	Max	T_{in}	T_{out}		
20	Import		-15.8	-27.3	-9.0	-15.6				
20	HEX	Evaporation	5.7	9.3	3.3	5.3	175	175		
20	HEX	Heating	7.7	22.1	4.4	12.6	160	190		
20	Letdown		2.6	7.2	1.5	4.1				
20	Losses		1.0	1.8	0.6	1.0				
20	HEX	Condensation	-1.3	-2.4	-0.7	-1.3	325	295		
	Total cons.		17.1	28.4	9.8	16.3				
5	HEX	Condensation	-3.9	-7.3	-2.3	-4.4	218	217		
5	HEX	Evaporation	3.7	6.5	2.2	3.9	116	134		
5	Losses		1.1	2.0	0.7	1.2				
5	Other		1.5	3.1	0.9	1.9				
	Total cons.		6.4	10.7	3.8	6.5				
	Aero cooling	Cooling			0.0	0.0	140	85		
	Water cooling	Cooling			12.4	18.4	100	65		

Appendix A. Process Units

Table A7 – Mean hot and cold stream data for Site Site R.

Name	Type	P	T ₁	Q ₁	T ₂	Q ₂	T ₃	Q ₃	T ₄	Q ₄	T ₅	Q ₅	T ₆	Q ₆	T ₇	Q ₇	T ₈	Q ₈	T ₉	Q ₉	T ₁₀	Q ₁₀	
S1A MIP strip	Gons	21	180	1.4	180																		
S1A MIP loss	Gons	21	25	0.6	26																		
S1A BP inj	Gons	6	110	0.5	110																		
S1A BP trac	Gons	6	65	1.1	65																		
S1A BP loss	Gons	6	25	0.3	26																		
S1A BP chek	Gons	6	63	0.8	63																		
S1A BP phlex	Prod	6	220	1.0	210	0.8	110	1.5	112														
S1A AERO1	Aero		153	0.5	132	0.5	123	0.5	118	0.5	114	0.5	108	0.5	99	0.5	95	0.5	86	0.5	75	0.5	53
S1A AERO2	Aero		148	0.4	138	0.4	134	0.4	128	0.4	124	0.4	119	0.4	114	0.4	104	0.4	94	0.4	84	0.4	54
S1A AERO3	Aero		130	0.5	120	0.5	114	0.5	113	0.5	104	0.5	100	0.5	93	0.5	84	0.5	61				
S1A AERO3 bis	Aero		178	0.5	152	0.5	133	0.4	125	0.4	112	0.4	106	0.4	93	0.4	77	0.4	46				
S1A AERO4	Aero		146	0.4	139	0.4	133	0.4	133	0.4	125	0.4	112	0.4	106	0.4	93	0.4	77	0.4	46		
S1A AERO4 bis	Aero		189	0.4	160	0.4	146	0.1	64	0.1	63	0.1	62	0.1	59	0.1	58	0.1	55	0.1	52	0.1	45
S1A AERO5	Aero		75	0.1	69	0.1	66	0.1	66	0.1	64	0.1	63	0.1	62	0.1	59	0.1	58	0.1	55	0.1	45
S1A CW1	CW		145	0.2	143	0.2	142	0.2	141	0.2	141	0.2	141	0.2	141	0.2	141	0.2	140	0.2	140	0.2	139
S1A CW2	CW		65	0.0	40																		
S1A CW3	CW		181	0.3	178	0.3	175	0.3	167	0.3	167	0.3	167	0.3	167	0.3	167	0.3	167	0.3	167	0.3	167
S1A CW3 bis	CW		208	0.3	199	0.3	191	0.3	188	0.3	188	0.3	186	0.3	185	0.3	182	0.3	181				
S1B MIP inj	Gons	21	160	0.5	160																		
S1B MIP chek	Gons	21	170	0.9	170	1.5	180	0.6	190														
S1B MIP loss	Gons	21	25	0.5	26																		
S1B BP phlex	Prod	6	210	0.2	200	0.5	195	0.7	191	1.0	189												
S1B BP trac	Gons	6	85	0.5	85																		
S1B BP loss	Gons	6	25	0.3	26																		
S1B BP chek	Gons	6	115	0.8	115	0.7	125																
S1B AERO1	Aero		78	3.6	45																		
S1B AERO2	Aero		70	1.9	45																		
S1B AERO3	Aero		59	1.8	45																		
S1B CW1	CW		94	2.7	34																		
S1B CW2	CW		120	2.6	29																		
S1C HP phlex	Prod	90	550	3.2	550	3.2	500																
S1C MIP loss	Prod	90	25	0.5	26																		
S1C MIP chek	Gons	21	150	2.3	160	2.3	170	2.3	180	3.5	190	1.2	200										
S1C MIP phlex	Prod	21	600	3.2	600																		
S1C BP inj	Gons	6	120	1.3	120																		
S1C BP loss	Gons	6	25	0.7	26																		
S1C BP trac	Gons	6	75	1.8	75																		
S1C BP chek	Gons	6	75	0.4	80	0.7	80	0.7	115	1.6	310	1.0	305	0.3	300								
S1C BP phlex	Prod	6	350	1.0	340	0.5	330	0.8	320														
S1A MIP strip	Gons	21	180	1.4	180																		
S1A MIP loss	Gons	21	25	0.6	26																		
S1A BP inj	Gons	6	110	0.5	110																		
S1A BP trac	Gons	6	65	1.1	65																		
S1A BP loss	Gons	6	25	0.3	26																		
S1A BP chek	Gons	6	63	0.8	63																		
S1A BP phlex	Prod	6	220	1.0	210	0.8	110	1.5	112														

Table A.8 – Mean hot and cold stream data for Site Site R.

Name	Type	P	T ₁	Q ₁	T ₂	Q ₂	T ₃	Q ₃	T ₄	Q ₄	T ₅	Q ₅	T ₆	Q ₆	T ₇	Q ₇	T ₈	Q ₈	T ₉	Q ₉	T ₁₀	Q ₁₀	
SIA AERO1	Aero		153	0.5	132	0.5	123	0.5	118	0.5	114	0.5	108	0.5	99	0.5	95	0.5	86	0.5	75	0.5	53
SIA AERO2	Aero		148	0.4	138	0.4	134	0.4	128	0.4	124	0.4	119	0.4	114	0.4	104	0.4	94	0.4	78	0.4	54
SIA AERO3	Aero		130	0.5	120	0.5	114	0.5	113	0.5	104	0.5	100	0.5	93	0.5	84	0.5	61				
SIA AERO3 bis	Aero		178	0.5	152	0.5	130																
SIA AERO4	Aero		146	0.4	139	0.4	133	0.4	125	0.4	112	0.4	106	0.4	93	0.4	77	0.4	46				
SIA AERO4 bis	Aero		189	0.4	160	0.4	146																
SIA AERO5	Aero		75	0.1	69	0.1	66	0.1	64	0.1	63	0.1	62	0.1	59	0.1	58	0.1	55	0.1	52	0.1	45
SIA CW1	CW		145	0.2	143	0.2	142	0.2	141	0.2	141	0.2	141	0.2	141	0.2	140	0.2	140	0.2	139	0.2	138
SIA CW2	CW		65	0.0	40																		
SIA CW3	CW		181	0.3	178	0.3	175	0.3	167	0.3	186	0.3	185	0.3	182	0.3	181						
SIA CW3 bis	CW		208	0.3	199	0.3	191	0.3	188	0.3	186	0.3	185	0.3	182	0.3	181						
SIB MP inj	Cons	21	160	0.5	160																		
SIB MP chex	Prod	21	170	0.9	170	1.5	180	0.6	190														
SIB MP loss	Cons	21	25	0.5	26																		
SIB BP phlex	Prod	6	210	0.2	200	0.5	195	0.7	191	1.0	189												
SIB BP trac	Cons	6	85	0.5	85																		
SIB BP loss	Cons	6	25	0.3	26																		
SIB BP chex	Cons	6	115	2.8	115	0.7	125																
SIB AERO1	Aero		78	36	45																		
SIB AERO2	Aero		70	19	45																		
SIB AERO3	Aero		59	18	45																		
SIB CW1	CW		94	2.7	34																		
SIB CW2	CW		120	2.6	29																		
SIC HP phlex	Prod	90	550	3.2	550	3.2	500																
SIC MP loss	Prod	30	25	0.5	26																		
SIC MP chex	Cons	21	150	2.3	160	2.3	170	2.3	180	3.5	190	1.2	200										
SIC MP phlex	Prod	21	600	3.2	600																		
SIC BP inj	Cons	6	120	1.3	120																		
SIC BP loss	Cons	6	25	0.7	26																		
SIC BP trac	Cons	6	75	1.8	75																		
SIC BP chex	Cons	6	75	0.4	80	0.7	80	0.7	115														
SIC BP phlex	Prod	6	350	1.0	340	0.5	330	0.8	320	1.6	310	1.0	305	0.3	300								
SIC AERO1	Aero		168	2.2	120																		
SIC AERO2	Aero		214	4.3	140																		
SIC AERO3	Aero		79	3.1	50																		
SIC AERO4	Aero		157	5.3	120																		
SIC CW1	CW		120	0.8	33																		
SIC CW2	CW		140	2.4	94																		
SIC CW3	CW		50	2.0	41																		
SIC CW4	CW		120	4.0	29																		
SID BP phlex	Prod	6	204	2.9	203	0.7	197																
SID BP chex	Cons	6	125	6.0	125																		
SID BP loss	Cons	6	25	0.2	26																		
SID BP inj	Cons	6	127	0.5	127																		

Table A.9 – Mean hot and cold stream data for Site Site R.

Name	Type	P	T ₁	Q ₁	T ₂	Q ₂	T ₃	Q ₃	T ₄	Q ₄	T ₅	Q ₅	T ₆	Q ₆	T ₇	Q ₇	T ₈	Q ₈	T ₉	Q ₉	T ₁₀	Q ₁₀	
STD BP trac	Cons	6	49	1.1	49																		
STD MP loss	Cons	6	25	0.3	26																		
STD MP phlex	Prod	21	315	0.6	314	0.6	312	1.2	300	1.8	295	1.8	290	1.4	165	0.9	170	0.9	180				
STD MP chek	Cons	21	125	0.9	130	0.9	135	1.8	145	1.4	150	0.9	160	1.4	165	0.9	170	0.9	180				
STD HP phlex	Prod	90	615	8.9	615																		
STD VBP phlex	Prod	2	180	1.0	180																		
STD VBP trl	Cons	2	75	0.6	76																		
STD VBP trac	Cons	2	60	0.4	70	0.5	80	0.4	85														
STD AERO1	Aero		130	2.2	45																		
STD AERO1 bis	Aero		171	1.2	130																		
STD AERO2	Aero		138	2.8	60																		
STD CW1	CW		50	0.8	29																		
STD CW2	CW		79	8.2	45																		
SIE MP chek1	Cons	21	160	0.6	185	1.5	185	0.9	190														
SIE MP losses	Cons	21	25	0.7	26																		
SIE MP chek2	Cons	21	120	0.8	125	1.5	130	1.2	135	0.9	145	1.0	150	0.8	155	0.4	166	1.2	170				
SIE BP chek1	Cons	6	110	1.8	110																		
SIE BP losses	Cons	6	25	0.5	26																		
SIE BP chek2	Cons	6	90	0.6	92	1.1	93	1.7	95	2.0	97	0.3	100										
SIE AERO1	Aero		110	1.5	45																		
SIE AERO2	Aero		114	2.3	45																		
SIE CW1	CW		65	7.2	35																		
SIE BP phlex	Prod	6	218	1.8	217																		
SIF BP chek	Cons	6	110	0.6	118	1.0	129	0.4	134														
SIF BP loss	Cons	6	25	0.7	26																		
SIF BP other	Cons	6	130	0.8	130																		
SIF MP phlex	Prod	21	325	0.2	315	1.0	315	0.1	295														
SIF MP loss	Prod	21	25	0.5	26																		
SIF MP chek2	Cons	21	160	1.1	185	2.3	185	1.1	190														
SIF CW1	CW		73	7.3	44																		
SIF CW2	CW		99	0.9	35																		
SIF CW3	CW		104	2.7	48																		
SIF CW4	CW		93	1.5	29																		
STU MP trac	Cons	21	160	4.5	180	8.9	180	4.5	190														
STU1 MP trac	Cons	6	70	3.7	70																		
STU1 MP trac	Cons	21	160	0.9	180	1.8	180	0.9	190														
STU1 BP trac	Cons	6	60	6.9	60																		
STUOSSES BP	Cons	6	25	2.9	26																		
STUOSSES MP	Cons	6	25	4.2	26																		
STU PREMP	Cons	21	110	3.1	150																		
STU PREBP	Cons	6	25	2.3	110																		
STU DEGAZ	Cons	6	145	11.4	145																		

Table A.10 – Mean turbine properties for Site R.

Name	P_{in} [barg]	P_{out} [barg]	η [-]	Steam load [t/h]	Power [MW]
S1 SHP HHP TURMP1	90.2	21.0	0.76	84.4	6.79
S1 SHP HHP TURMP2	90.2	21.0	0.41	36.6	2.92
S1 SMP HMP TURUTILS	21.0	6.1	0.35	26.8	0.63
S1A MP turb	21.0	6.1	0.30	7.3	0.15
S1C HP turb BP	90.2	6.1	0.40	11.3	0.77
S1C HP turb MP	90.2	21.0	0.40	9.9	0.42
S1D MP turb	21.0	6.1	0.30	0.3	0.01

A.2 Site P Process Units

All process requirements are defined using True Boiling Point definitions and are shown in Tables A.17 and A.18. For injections, the pressure of the columns are given. This pressure can be used to calculate the minimum injection pressure of the steam.

Turbine isentropic efficiencies are also supplied so as to calculate the steam cogeneration. Their overview is presented in Table A.19.

Losses are not considered inside the process units of Site P.

Unit A - Cracker




Figure A.7 – Schematic of the steam network of Site P Unit A.