Optimal Heat Pump Integration in Industrial Processes

Anna S. Wallerand^{*1}, Maziar Kermani¹, Ivan Kantor¹, and François Maréchal^{†1}

¹*École Polytechnique Fédérale de Lausanne (EPFL) Valais Wallis, Switzerland*

Abstract

Among the options for industrial waste heat recovery and reuse which are currently discussed, heat pumping receives far less attention than other technologies (e.g. organic rankine cycles). This, in particular, can be linked to a lack of comprehensive methods for optimal design of industrial heat pump and refrigeration systems, which must take into account technical insights, mathematical principles and state-of-the-art features. Such methods could serve in a twofold manner: (1) in providing a foundation for analysis of heat pump economic and energetic saving potentials in different industries, and further (2) in giving directions for experimentalists and equipment manufacturers to adapt and develop heat pump equipment to better fit the process needs.

This work presents a novel heat pump synthesis method embedded in a computational framework to provide a basis for such analysis. The superstructure-based approach is solved in a decomposition solution strategy based on mathematical programming. Heat pump features are incorporated in a comprehensive way while considering technical limitations and providing a set of solutions to allow expert-based decision making at the final stage.

Benchmarking is completed by applying the method on a set of literature cases which yields improved-cost solutions between 5 and 30% compared to those reported previously. An extended version of one case is presented considering fluid selection, heat exchanger network (HEN) cost estimations, and technical constraints. The extended case highlights a trade-off between energy efficiency and system complexity expressed in number of compression stages, gas- and sub-cooling. This is especially evident when comparing the solutions with 3 and 5 compression stages causing an increase of the coefficient of performance (COP) from 2.9 to 3.1 at 3% increase in total annualized costs (TAC).

Keywords: industrial refrigeration; fluid selection; MINLP superstructure; multi-objective optimization; genetic algorithm; waste heat recovery and valorization;

^{*}anna.wallerand@epfl.ch, anna.wallerand@gmail.com

[†]francois.marechal@epfl.ch

Acronyms

Capex	Annualized capital expenses
CEPCI	Chemical engineering's plant cost index
COP	Coefficient of performance
GWP	Global warming potential
HEN	Heat exchanger network
HFC	Hydrofluorocarbons
HPS	Heat pump superstructure
LNG	Liquid natural gas
LP	Linear programming
MILP	Mixed integer linear programming
MINLP	Mixed integer nonlinear programming
MIP	Mixed integer programming
MOGA	Multi-objective genetic algorithm
NLP	Nonlinear programming
Opex	Yearly operating expenses
ORC	Organic rankine cycle
PA	Pinch analysis
PI	Process integration
TAC	Total annualized costs
TSA	Total site analysis

1 Introduction

Heat pumping has gained increasing attention during the past decades not only for household applications but also for improving energy efficiency of industrial processes through waste heat recovery and valorization at elevated temperatures [1, 2]. As demonstrated in Appendix A.1 (Figure 11), research in the field of industrial *waste heat recovery* is largely dominated by organic rankine cycle (ORC) applications and thermoelectric devices. This may stem from a fully explored state-of-the-art of industrial heat pumps and integration methods; however, the marginal penetration of industrial heat pump systems (apart from basic refrigeration and air-conditioning) [2, 3] contradicts this notion. The main barriers for broad usage in industry were identified as lack of knowledge and of comprehensive heat pump integration methods to provide improvement potentials [2, 3]. This work mainly covers single fluid, mechanically driven systems due to their advanced technological development and operative flexibility (see Appendix A.1 for more explanation). After a state-of-the-art analysis of current synthesis methods, this work presents a novel heat pump superstructure with a bi-level solution strategy in the methodology section, followed by application of the method to various literature cases in the results and discussion section.

2 State-of-the-art

The focus of this work lies on mechanically driven heat pump synthesis methods for industrial processes. Since these techniques rely on modeling state-of-the-art heat pump technologies, a short review of available heat pump features was conducted. Chua et al. [2] and most recently Arpagaus et al. [4] presented comprehensive literature reviews on advances in mechanically driven (multi-temperature) heat pump systems. The most recurring features relevant for large-scale modeling of industrial heat pumps were identified and are presented in Table 1. These include multi-stage compression and expansion, ejectors, cascaded cycles, gas-cooling, subcooling, economizers, and presaturators. Other developments, which impose different system architectures (desiccant cooling [2]) or more refined equipment modeling (scroll and oil-free compressors [2, 4–6]) are not discussed in this work.

Table 2 provides an overview of the studies introducing synthesis methods discussed in this section. In the presented approaches, it is differentiated between conceptual methods which are based on expert judgment, heuristic rules, or graphical analysis; and mathematical methods, which rely on mathematical programming to perform systematic optimization. This work presents a contribution to the latter which is thus discussed at greater length.

2.1 Conceptual methods

Conceptual, or insight-based, methods are not limited by the problem size and therefore always lead to a solution though global optimality will seldom be reached. As early as 1974, Barnés and King [7] and later Cheng and Mah [8] proposed methods based on a set of heuristic rules, dynamic programming, and expert judgment for synthesis of industrial heat pump systems. In 1978, a milestone was achieved, when Linnhoff and Flower [9] proposed a method now commonly known as pinch analysis (PA) [10] which, for the first time, allowed systematic analysis of a process net thermodynamic requirements and maximum heat recovery potential. This led Townsend and Linnhoff [11] to derive the theoretical foundation for ideal placement of heat engines and heat pumps based on the principles of PA. They concluded that system

Table 1: Heat pump features considered in this work as identified by [2, 4].

Feature	Description		Feature	Description	
(A) Multi-stage compression [4, 13–15]	Provide higher COP through intermediate vapor cooling while imposing challenges for direct vapor injection (multi-stage compressor) or lubrication management (multiple single-stage compressors)		(B) Multi-stage expansion (inter-cooling) [16, 17]	Offers lower technical complexity and higher performance through cooling at intermediate pressure level (with aid of several expansion valves for a single-stage compressor)
(C) Cascaded cycles [18]	Enable coverage of wider temperatures ranges due to the possibility of working fluids switching with applications in natural gas liquefaction or other cryogenic processes, or waste heat recovery with a strong temperature lift		(D) Gas-cooling [19]	Allows to recover heat from the superheated vapor at the compressor outlet (e.g. in a separate heat exchanger), and therefore generates a multi-temperature profile at a single pressure level at higher capital expenses
(E) Economizer [19]	Permits to preheat the saturated vapor before entering a compressor by mixing with superheated vapor at the same pressure level		(F) Subcooling [15, 17, 18]	Subcooling before expansion improves the performance of heat pumps, however, possibly at the cost of additional heat exchanger installation
(G) Presaturators (flash-drums) [15, 19, 20]	Enable to saturate superheated vapor and to remove flash gas between expansion stages which improves the coefficient of performance in multiple ways		(H) Ejectors [4, 17, 20–22]	Allow compression of a low pressure fluid through the expansion of a high pressure fluid (principle of suction) at low maintenance and capital expenses. <i>Ejectors were not considered in this work, but are mentioned due to their promising characteristics</i>

improvement from a thermodynamic standpoint can only be achieved if heat pumps are placed across the process pinch temperature (A.1). Industrial capital budgeting, however, is seldom based upon thermodynamic objectives. Other drivers play a major role including economic and environmental concerns as well as technical constraints. Therefore, subsequent researchers added thermo-economic principles and technical constraints into their decision process as shown e.g. by Ranade [12] with a trade-off formula between the temperature lift and heat exchanger cost in total site analysis (TSA) (see Table 2).

2.2 Mathematical methods

Mathematical methods ensure identification of an ideal point with regard the selected objective(s); however, convergence of optimization techniques becomes increasingly difficult with growing problem size. Therefore, many studies considered a reduced solution space, such as discretized temperature levels, simplified heat pump cycles, disregarding PA principles, or pre-selecting working fluids. The studies presenting mathematical methods are analyzed in the following paragraphs based on selected characteristics.

Temperature level selection In the literature, temperature level (used here interchangeably with pressure level) selection was handled in two ways. The primary approach relies on predefined or discretized temperature levels among which compressor units are activated using integer variables. The first comprehensive methodology for optimal industrial heat pump design based on discrete temperature levels was presented by Shelton and Grossmann [23][24] in the form of a mixed integer linear programming (MILP) superstructure. Many subsequent authors used discretized temperature levels (as depicted in Table 2), resulting in a diminished solution space and therefore increasing the risk of identifying a sub-optimal solution. Fewer authors presented methods with continuous temperature levels as part of the decision variables, which renders the problem structure nonlinear as presented e.g. by Colmenares and Seider [25].

Pinch analysis The principles of PA were considered in most methodologies listed in Table 2. Few authors presented algorithms neglecting PA, which reduced the problem size at the cost of disregarding the heat recovery system and its dependencies.

Heat pump features In modeling heat pump features, three approaches addressing different levels of detail were observed in the literature. In the first group (1), heat pump performance was modeled based on general thermodynamic principles. It aids in estimating potentials for improvements reachable with heat pump integration but lacks specification of real fluids or system design. Works contained in the second group (2) modeled basic single-stage heat pump cycles based on real fluids assuming that superposition of simple cycles could represent more complex systems. This leads to underestimation of performance and thus sub-optimal solutions could be generated. The third group (3) contains work presenting rigorous heat pump models including technical features from Table 1. Most of these included multi-stage compression and pre-saturation, while some additionally considered liquid sub-cooling, preheating before compression, or gas-cooling, and very few authors examined multi-stage expansion including Aspelund et al. [26]. No previous work has comprehensively included all identified heat pump features.

Objective function Apart from the work of Becker et al. [27], the works discussed here have presented mathematical approaches for single-objective optimization of industrial heat pump systems with objectives such as minimizing exergy losses or total cost. In praxis, decision-making is based on many factors and it is thus difficult to obtain the global solution from single-objective optimization. Therefore, it is advantageous to derive multiple solutions such that the final decision can be based on several criteria including expert judgment, which could be facilitated by multi-objective optimization.

Fluid selection Fluid selection has not been considered extensively in heat pumping literature. Some authors have compared different working fluids based on thermodynamic principles, such as Oluleye et al. [28], while others mainly derive the optimal mass flow rates or composition from preselected fluids, including Kamalinejad et al. [29]. Few researchers have integrated fluid selection into the optimization in the form of integer, binary, or continuous variables such as Becker [27], Vaidyaraman and Maranas [30], or Colmenares and Seider [31]. The candidate fluids were principally selected based on fluid critical properties and triple point.

2.3 Discussion and goal

The discussion of studies presenting conceptual and mathematical methods for optimal heat pump design and integration with industrial processes is summarized as follows.

1. Conceptual methods provide important insight to problems but cannot assess solution optimality. The advantage is, however, that technical infeasibilities and practical constraints can be considered without facing computational problems.
2. Mathematical methods may experience convergence issues for large scale problems due to increasing complexity. Therefore, many studies considered a reduced solution space.
3. Few studies provide a combination of conceptual and mathematical approaches, which can harvest the advantages of both methods, e.g. through introduction of technical constraints, or multi-solution generation.
4. The potential impact of heat pumping for industrial waste heat recovery is not clearly communicated.

This paper addresses the gaps denoted (2) and (3) by presenting a novel comprehensive superstructure synthesis method which is solved using mathematical programming for optimal integration of industrial heat pump systems. Preliminary versions of this heat pump superstructure (HPS) [32, 33] were generalized and extended to incorporate fluid selection, HEN

Table 2: Literature summary of synthesis methods for heat pump design and integration with industrial processes.

Authors	Year	Focus	Method		PA	Property calc.	Temp. discret.	Detail	Objective	Cycle features							Fluid	
			Conc.	Math.						(A)	(B)	(C)	(D)	(E)	(F)	(G)	T	Selection
<i>Current work</i>		HP	TC	MINLP	✓	CP	0.5 K	3	opex, capex	✓	✓	✓	✓	✓	✓	✓	S	✓ Integers
Zhang et al. [34]	2016	AHP		MINLP		-	contin.	1	TAC			✓					G	
Oluleye et al. [35]	2016	HP/AHP/HE/AHT	TP		✓	HYSYS	10 K	2	Fuel			✓					S	✓ TP
Oluleye et al. [36]	2016	HP/AHP/HE/AHT		MILP	✓	HYSYS	10 K	2	TAC			✓					S	✓ Binary
Dinh et al. [37]	2015	HP		MILP	✓	PR	fixed	3	Power	✓		✓			✓	✓	S	(✓) Flowrates
Kamalinejad et al. [29]	2015	HP		MINLP	✓	RP	contin.	3	TAC	✓		✓	✓	✓	✓	✓	S	(✓) Flowrates
Liu et al. [38]	2014	HP	TP		✓	-	fixed	3	Power	✓		✓					S	✓ TP
Khan and Lee [39]	2013	HP		NLP	✓	PR	contin.	3	Power	4(*)	✓	✓					M	(✓) Composition
Hackl and Harvey [40]	2013	HP	TP		✓	simple	fixed	1	-			✓					G	
Becker [27],[41]	2012	HP		MINLP	✓	Belsim	contin.	2	opex, capex			✓	✓		✓		S	✓ Binary
Zhang and Xu [42]	2011	HP	TC	MINLP	✓	-	fixed	3	Exergy	✓		✓	✓	✓	✓	✓	S	(✓) Flowrates
Hasan et al. [43]	2009	HP		MINLP		simple	contin.	3	Power	✓		✓				✓	S/M	(✓) Flowrates
Nogal et al. [44]	2008	HP		MINLP	✓	HYSYS	contin.	3	capex/Power							✓	M	(✓) Composition
Aspelund et al. [26]	2007	HP	TP			HYSYS, SRK	fixed	3	Exergy	✓	✓	✓				✓	S	✓ TP
Bagajewicz and Barbaro [45]	2003	HP		NLP	✓	simple	contin.	1	opex			✓					G	
Holiastos and Manousiouthakis [46]	2002	HE/HP		LP	✓	simple	fixed	1	TAC			✓					G	
Vaidyaraman and Maranas [47]	2002	HP		NLP	✓	SRK	contin.	3	Power		✓	✓				✓	M	(✓) Composition
Maréchal and Kalitventzeff [48]	2001	HP	TC	MILP	✓	Belsim	fixed	3	Exergy	✓		✓				✓	S	✓ Binary
Vaidyaraman and Maranas [30]	1999	HP		MILP	✓	[49]	1- 8 K	3	TAC	✓		✓		✓		✓	S	✓ Binary
Kauf [50]	1999	HP	TP			-	contin.	2	COP								S	
Wallin and Berntsson [51]	1993	HP/AHP/AHT	TEP		✓	generic	fixed	1	TAC							✓	G	
Linnhoff and Dhole [52]	1992	HP	TP		✓	simple	fixed	3	Power	✓		✓				✓	S	
Swaney [53]	1989	HE/HP		LP	✓	simple	fixed	3	TAC	✓		✓				✓	S	
Colmenares and Seider [25]	1989	HE/HP		NLP	✓	PR	contin.	2	TAC			✓					S	✓ Flowrates
Ranade [12]	1988	HP	EP		✓	simple	contin.	1	TAC								G	
Colmenares and Seider [31]	1987	HE/HP		NLP	✓	PR	fixed	2	TAC			✓					S	✓ Flowrates
Shelton and Grossmann [23]	1986	HP		LP	✓	[54]	1 K	3	TAC	✓		✓				✓	S	
Shelton and Grossmann [24]	1986	HP		MILP	✓	[54]	10 K	3	TAC	✓		✓				✓	S	
Townsend and Linnhoff [11]	1983	HE/HP	TP		✓	Tabl.	fixed	2	Exergy								S	
Cheng and Mah [8]	1980	HP	HR			SRK	contin.	3	TAC	✓		✓	✓	✓	✓	✓	S	✓ TP
Barnés and King [7]	1974	HP	HR	MIP		SRK	contin.	3	TAC	✓		✓	✓	✓	✓	✓	S	

(*) Fixed four stages in optimization study

Focus: HP - compression heat pumps, HE - heat engines, AHP - absorption heat pumps, AHT - absorption heat transformers

Conceptual methods: TP - Thermodynamic principles, TC - Technical constraints, EP - Economic principles, HR - Heuristic rules, TEP - Thermo-economic principles;

PA: pinch analysis [10, 55]

Property calculation: CP - CoolProp [56], RP - Refprop [57], SRK - Soave-Redlich-Kwong [58] equation of state, HYSYS - Aspen HYSYS software [59], simple - simplified estimations, PR - Peng-Robinson [60], Belsim - Belsim Vali software [61]

Detail: Level of detail in modeling: 1 - general modeling based on thermodynamic estimations for a generic fluid, 2 - modeling of simplified (single-stage) cycles for specific fluids, 3- full detail modeling of (multi-stage) heat pumps with advanced features for different fluids

Objective: TAC (min), Fuel - primary fuel consumption (min), Exergy - exergy losses (min), opex (min), capex (min), Power - compression power (max)

Cycle features: (A) Multi-stage compression, (B) multi-stage expansion, (C) cascaded cycles, (D) gas cooling, (E) Economizer (preheating before compression), (F) sub-cooling, (G) presaturators

Fluid: T (types): S - single component fluid, M - fluid mixture, G - generic fluid; Selection: TP: thermodynamic principles

cost estimation, technical constraints and a comprehensive list of heat pump features. A multi-objective decomposition solution strategy allows convergence for large problems and provides multiple solutions for expert judgment adapted to the diverse criteria relevant in industry. This strategy addresses the shortcomings of previous work and provides a clear design method based on a comprehensive superstructure and mathematical programming.

3 Methodology

3.1 Problem statement

Given an industrial process with thermal and material demands and a set of candidate utility technologies, including potential heat pumps, the goal is to find the optimal utility system including the optimal design of the heat pump system. The optimal heat pump layout should encompass specification of technologies, features, working fluid and operating conditions. This method, therefore, aims at providing a utility target and preliminary design of the heat pump system as the basis for detailed design considering dynamic behavior in a subsequent step.

3.2 Superstructure synthesis

A flowsheet and a temperature entropy diagram of the novel heat pump superstructure (HPS) are depicted in Figure 1. It illustrates the various potential pathways and features considered in the superstructure. Some features are represented in sample cycles.

The superstructure is equipped with a condenser and evaporator at the highest and lowest pressure levels, respectively. The intermediate levels additionally contain a presaturator, a post-compression gas-cooler, a subcooling heat exchanger, and a superheater. Compressors and valves are made available between all pressure levels. Superheated vapor exiting the compressor can be de-superheated in a heat exchanger (gas-cooler) and condensed (represented by one heat exchanger), and/or sent to a presaturator which saturates the fluid and separates it into its phases. Two-phase flow leaving the expansion valves can be evaporated (and potentially superheated by mixing or heat exchange) and then compressed or mixed with condensate with options of inter-cooling and/or subcooling before expansion.

3.3 Mathematical formulation

The statement above corresponds to a non-convex Mixed Integer Nonlinear Programming (MINLP) problem. The integer variables relate to activation of different technology options while nonlinearities mainly arise from capital cost correlations and the intrinsic nonlinearity of thermodynamic property correlations. Therefore, a decomposition strategy [62] is applied as presented in Figure 2 which incorporates the nonlinearities at the master level solving the linear problem at the slave level. The variables present in the nonlinear constraints are set at the master level and thus act as parameters for the slave optimization. At the slave level, the linear problem is solved and the decision variables contained in the linear constraints and the linear objective function are transferred to a post-computational analysis where the nonlinear capital cost correlations and objectives are calculated. Based on the objective function values, a convergence check is performed and a new iteration is initiated at the master level.

The main assumptions considered in the heat pump superstructure are:

- the thermodynamic behavior is at steady-state
- heat losses and pressure drops in piping and the components are negligible
- the outlet of a condenser is either saturated or subcooled

- the outlet of an evaporator is either saturated or superheated
- isenthalpic expansion in the valves
- the minimum approach temperature difference is fixed for every stream (and follows the indications from the literature cases)

The conventions in the equations presented below are that scalar decision variables are represented by italic letters, scalar parameters by roman text, vectors are always represented in bold (italic for variables, roman for parameters), and sets are represented in roman bold uppercase.

3.3.1 Master level

At the master level, a black box optimization is performed where the variables present in the nonlinear constraints are the decision variables. These are mainly the heat pump saturation temperature levels (T_i), the fluid (d), the subcooling, gas cooling, and compressor preheating temperature differences ($\Delta T_{i,SC}$, $\Delta T_{i,DSH}$, $\Delta T_{i,PRE}$), and all thermodynamic properties derived from these. An additional variable is introduced in order to vary the weight (ξ) of the two components in the objective function at the slave level (see section 3.3.2 - objective function). The properties are retrieved from the open-source database CoolProp [56]. The variables and objective functions at the master level are found in Table 3. Black-box multi-objective nonlinear optimization is performed by Dakota [64] using a multi-objective genetic algorithm (MOGA) [65] which allows analysis of a wide solution space. The specifications used are presented in appendix A.2.

Objective function Different objective functions are of interest when optimizing industrial heat pumps such as the exergy efficiency, coefficient of performance (COP), environmental impact, or cost. Based on the literature cases considered in the results and discussion section, the objectives of the multi-objective optimization were based on economic criteria, i.e. annualized capital expenses (capex) and yearly operating expenses (opex) as shown in Equation 1.

Figure 1: Flowsheet and temperature-entropy diagram of the HPS with sample cycles.

Figure 2: Flowchart of decomposition strategy solving MINLP superstructure implemented in Lua OSMOSE platform [62, 63].

$$\min_{T_i, \Delta T_{i,DSH}, \Delta T_{i,SC}, \Delta T_{i,PRE}, d, \xi} \{C^{opex}, C^{capex}\} \quad (1)$$

The capex (depicted in Equation 4) consists of the investment costs of all technologies w and the HEN cost estimation calculated using Equation 3. The HEN area is estimated as suggested by Townsend and Linnhoff [10, 66] based on vertical intervals in the composite curves. HEN design based on mathematical principles, as well as optimization of the minimum approach temperature (ΔT_{min}) was not performed in this work, but could be added to the solution strategy.

Link to slave level The utility and heat pump technology sizing is performed at the slave level. The results from the slave optimization serve as input to calculate the master level objective functions. These are the maximum size (f^w) and existence (y^w) of each technology w influencing the equipment investment and heat exchanger network cost estimation.

3.3.2 Slave level

The HPS is embedded in the utility targeting problem of Maréchal and Kalitventzeff [68] where the optimal utility system for an industrial process is found based on the thermal and material needs considering maximum heat recovery. This means that all elements of the heat pump, namely condensers, evaporators, compressors, presaturators (flash-drums) and gas-coolers, are present as utility technologies in the targeting approach. The main variables at the slave level are the size and existence of each utility technology, including all heat pump elements. The size of each technology is decided by optimization based on the objective function while remaining subject to physical and thermodynamic laws. To ensure mass and energy conservation within the heat pump, additional constraints are added at all saturated liquid, vapor, and superheated vapor points. Since the saturation temperature and respective pressure levels as well as the subcooling and superheated properties are set at the master level, component sizing is linearly dependent on the state properties. Therefore, the problem can be described as a multi-period Mixed Integer Linear Programming (MILP) problem which is solved using commercial software (AMPL modeling language [69]) with CPLEX [70]. Table 4 depicts the objective function and variables at the slave level. The utility targeting constraints are described in further detail in appendix C.1. The heat pump parameters for utility targeting as well as mass and energy balances are found in appendix C.2.

Objective function The MILP problem is solved with commercial solvers based on branch and cut methods for a single objective function. Investigation of a wide solution space regarding both objectives from the master level leaves two options for consideration.

Table 3: Variables and objective function at master level.

Description	Symbols	Equation
<i>Objectives</i>		
Yearly operating ex-penses (opex) [\$ / y]	C^{opex}	from slave level, see Table 4
Total investment cost [\$]	C^{INV}	$\sum_{w \in \mathbf{W}} C^w(f^w, y^w) + C^{HEN} \quad (2)$
	$\mathbf{W}$ f^w y^w C^w	set of utility technologies w maximum size of technology w existence of technology w investment cost function of technology w , see appendix C.2
Heat exchanger network cost (*) [\$]	C^{HEN}	$\max_p \left\{ \left[c_1 + c_2 \cdot \left(\frac{A_{tot,p}^{HEN}}{N_{min,p}^{HEN}} \right)^{c_3} \right] \cdot N_{min,p}^{HEN} \right\} \quad (3)$ $A_{tot,p}^{HEN} = \sum_{k \in \mathbf{K}} \frac{1}{\Delta T_{log,k}} \cdot \left[\sum_{c \in \mathbf{C}} \frac{\dot{Q}_{p,k}^c}{\alpha^c} + \sum_{h \in \mathbf{H}} \frac{\dot{Q}_{p,k}^h}{\alpha^h} \right] (*)$
	$\mathbf{K}$ $\mathbf{H}, \mathbf{C}$ $\Delta T_{log,k}$ $\dot{Q}_{p,k}^{h,c}$ α^h, α^c $A_{tot,p}^{HEN}$ $N_{min,p}^{HEN}$ c_1 c_2 c_3	set of temperature intervals $\{1, 2, 3, \dots, m_k\}$ set of hot, cold process and utility streams set of cold process and utility streams [K] logarithmic mean temperature difference $f_p^{h,c} \cdot \dot{Q}_{p,k}^{h,c}$ [kW] contribution of hot h , cold stream c to temperature interval k in period p [kW/m ² K] hot, cold stream h, c heat transfer coefficient [m ²] total heat exchanger network area [-] minimum number of heat exchanger units [\$] fixed cost parameter [\$/m ²] scaling cost parameter [-] non-linear parameter
Annualized capital ex-penses (capex) [\$ / y]	C^{capex}	$C^{INV} \cdot (\tau + m) \quad (4)$
	τ m	[-] $\frac{\tau(1+\tau)^n}{(1+\tau)^n - 1}$ investment cost annualization factor [-] maintenance cost as fraction of total investment
Total annualized costs (TAC) [\$ / y]	C^{TAC}	$C^{capex} + C^{opex} \quad (5)$
<i>Variables</i>		
Temperature levels	T_i	$[T_i^{\min}, T_i^{\max}]$, [K] saturation temperature levels
Subcooling	$\Delta T_{i,SC}$	$[0, T_{i,SC}^{\max}]$, [K] temperature difference between condensate and subcooling outlet
De-superheating	$\Delta T_{i,DSH}$	$[0, T_{i,DSH}^{\max}]$, [K] temperature difference in gas-cooling heat exchanger
Pre-heating	$\Delta T_{i,PRE}$	$[0, T_{i,PRE}^{\max}]$, [K] temperature difference for preheating before compression
Fluid index	d	$\{1, 2, \dots, n_d\}$ from set of fluids $\mathbf{F}$
Weighting factor	ξ	$[0, 1]$, [-] for objective function of slave optimization

(*) Area estimation based on [10, 66]. The minimum number of heat exchangers (units) N_{min}^{HEN} is estimated following the suggestion of Linnhoff et al. [67] based on graph theory.

- Constraining one objective with a variable controlled from the master level and minimizing the second objective or
- Defining a weighted sum of the two objectives (wC^{TAC}) where the weighting factor (ξ) is controlled at the master level.

Since alternative (a) generates more infeasible solutions and therefore leads to longer solution times, option (b) was selected and is expressed in Equation 6.

$$\min_{f_p^w, f^w, y_p^w, y^w} \{wC^{TAC}\} \quad (6)$$

Heat cascade The MILP slave model is subject to heat cascade constraints [68] which ensure heat transfer feasibility for maximum heat recovery. The set of equations are provided in appendix C.1 (Equation 13 - Equation 14).

Mass and energy balances All material and non-thermal energy requirements are described by a set of constraints. These equality constraints ensure that material/energy consumption

and conversion are balanced within the system boundaries or compensated with help of the grid (utilities) which factors into the operating cost.

Variables The variables present at the slave level are the existence (y_p^w) and sizing (f_p^w) of each of the utility technologies w during each period p and the maximum size considering the entire operating range. Based on the objective function and thermodynamic input parameters selected at the master level, optimal sizes and operating conditions of all utilities including the heat pump technologies are derived within the optimization.

Heat pump specific constraints The general heat pump parameters such as the reference heat load of the evaporator and condenser and the reference electricity consumption of the compressors are presented in appendix C.2.1. These enter into the targeting constraints and are sized based on the process thermal requirements minimizing the objective function. Enforcing energy and mass conservation within the HPS requires additional constraints to be introduced. These are illustrated in further detail in appendix C.2.2. Mass and energy conservation are introduced at three different points on each pressure level, namely: the superheated vapor point after compression, the de-superheated or saturated vapor point before compression or condensation, and the saturated or subcooled liquid point after condensation or before evaporation. Since these points are fixed at the master level, all equations can be formulated with purely linear dependencies. Mass balances at all three points ensure that the working fluid mass flow rate is conserved throughout the heat pump system. Energy balance equations ensure that mixing (e.g. of two compressor outlets at the same pressure level) do not violate the energy conservation law. Superheated vapor mass and energy balances are introduced to study the effect of sensible heat recovery from the vapor (gas-cooling). This can either be achieved by installation of a separate heat exchanger (gas-cooler) or by accounting for sensible heat release in the condenser unit. Both options are separately modeled in this superstructure but does not have a major impact on the heat exchanger network cost estimation (since gas cooling in both cases imposes higher investment). The de-superheating temperature difference ($\Delta T_{DSH,i}$) selected at the master level can be understood as the temperature from which sensible heat release is considered. This temperature difference does not influence the energy balance but by manipulating the inlet temperature of the de-superheating, HEN solutions which require stream splitting can be avoided, which has an influence on the heat cascade. If it is set to zero, gas-cooling is neglected and the sensible heat contained in the superheated vapor is considered as if it was available only at saturation temperature levels.

Apart from energy and mass conservation, technical constraints can be considered as introduced below.

Number of heat pump stages The maximum number of stages of a heat pump cycle consisting of one fluid can be restricted as shown in Equation 7.

$$\sum_{i=2}^{n_1} \sum_{j=1}^{i-1} y^{g, \text{comp } i \rightarrow j} \leq n_g^{\max} \quad \forall g \in \mathbf{G} \quad (7)$$

Where

$\mathbf{G}$	set of heat pumps with one working fluid
$\mathbf{L}$	set of saturation temperature levels $\{1, 2, 3, \dots, n_1\}$
$y^{g, \text{comp } i \rightarrow j}$	overall existence of compressor between level i and j of heat pump g
$n_g^{\max}$	maximum number of heat pump stages of heat pump g

Compression ratio and minimum pressure Compressors with compression ratios or with pressure levels outside the bounds cannot be activated as depicted in Equation 8.

$$\left\{ y^{g, \text{comp } i \rightarrow j} = 0 \mid \frac{p^{g,j}}{p^{g,i}} > \text{CR}_g^{\max} \vee \frac{p^{g,j}}{p^{g,i}} < \text{CR}_g^{\min} \vee p^{g,i} < p^{\min} \right\} \quad \forall i, j \in \mathbf{L} \mid j < i, g \in \mathbf{G} \quad (8)$$

Where

$p^{g,k}$	[bar] saturation pressure level of heat pump g at saturation temperature level k
$\text{CR}_g^{\min, \max}$	[bar/bar] minimum, maximum accepted compression ratio of heat pump g
$p^{\min}$	[bar] minimum accepted saturation pressure level

Heat exchanger size A minimum size for heat exchangers is introduced in the form of a soft constraint. Thereby, a fixed penalty cost is added to the units containing thermal streams as shown in Equation 9.

$$C^{\text{fix}} = a \cdot \left(\frac{Q^{\min}}{U \cdot A \cdot \Delta T} \right)^b \quad \forall h \in \mathbf{H}^g, g \in \mathbf{G} \quad (9)$$

$$IV_1^h = C^{\text{fix}}$$

Where

$\mathbf{H}^g$	set of thermal heat pump units {condensers, evaporators, presaturators, gas-coolers} in heat pump g
U	[kW/m ² K] overall heat transfer coefficient
A	[m ²] reference heat exchange area
$Q^{\min}$	[kW] minimum heat exchanger size
ΔT	[K] log mean temperature difference in the heat exchangers
a, b	[\$,-] cost parameters

3.4 Fluid selection

Presuming fluid selection from known fluids and sub-critical operation, there are two options for conducting a fluid selection in the underlying method.

- (a) the list of candidate fluids is added to the **slave level**, in which every unit (condenser, evaporator, compressors, etc.) is reproduced as many times as there are fluids; the fluids are then activated using binary variables connected to the existence of each unit (y^w), or
- (b) an integer variable referencing the fluid is added to the **master level**

The advantage of selection at the slave level, (a), is that cascaded cycles with different fluids can be designed and convergence of the decomposition strategy is reached after fewer iterations (due to fewer variables at the master level). The disadvantage is that the slave problem size increases proportionally with the number of fluids which impacts the MILP resolution time significantly. Both options were applied in this study depending on the respective problem statement (which will be indicated).

4 Results and discussion

This section is divided into three parts. In the benchmarking analysis, three case studies presenting optimal heat pump designs for industrial processes from the literature were selected. The literature results were reproduced with the heat pump superstructure (HPS) to validate its flexibility. During the optimization study, the multi-objective bi-level approach presented in the methodology is applied to the three literature cases, and compared to the previous solutions from the literature. In an extended analysis, one literature case is expanded to consider fluid

Table 4: Variables and objective function at slave level.

Description	Symbols	Equation
<i>Objectives</i>		
Weighted total annualized costs (TAC) [\$ / y]	wC^{TAC}	$\xi \cdot C^{capex} + (1 - \xi) \cdot C^{opex} \quad (10)$
	ξ	weighting parameter controlled from master level
Yearly operating expenses (opex) [\$ / y]	C^{opex}	$\sum_{p \in \mathbf{P}} \left(\sum_{w \in \mathbf{W}} \text{OP}_{1,p}^w \cdot y_p^w + \text{OP}_{2,p}^w \cdot f_p^w \right) \cdot \Delta t_p \cdot \text{occ}_p \quad (11)$
Sizing constraint		$f_p^{w,\min} \cdot y_p^w \leq f_p^w \leq f_p^{w,\max} \cdot y_p^w \quad \forall p \in \mathbf{P}, w \in \mathbf{W}$
	$\mathbf{P}$	set of time periods $\{1, 2, 3, \dots, n_p\}$
	$\mathbf{W}$	set of utility technologies
	f_p^w	continuous variable for sizing technology w during period p
	y_p^w	binary variable related to existence of technology w during p
	$\text{OP}_{1,p}^w$	[\$ / h] fixed operating cost in period p
	$\text{OP}_{2,p}^w$	[\$ / h] proportional operating cost in period p
	Δt_p	[h] operating time of period p
	occ_p	[1 / y] occurrence of period p
Annualized capital expenses (capex) [\$ / y]	C^{capex}	$\sum_{w \in \mathbf{W}} \text{IV}_1^w \cdot y^w + \text{IV}_2^w \cdot f^w \quad (12)$
	f^w	maximum size of technology w
	y^w	overall existence of technology w
	IV_1^w	[\$ / y] fixed cost related to the annualized, linearized investment of technology w
	IV_2^w	[\$ / y] proportional cost related to the annualized, linearized investment of technology w
	w	
<i>Variables</i>		
Multiplication factor	f_p^w	$[f_p^{w,\max}, f_p^{w,\min}], [-]$ sizing factor of technology w during period p
Use factor	y_p^w	$\{0, 1\}, [-]$ existence of technology w in period p
Maximum multiplication factor	f^w	$\geq f_p^w \quad \forall p \in \mathbf{P}$ maximum size of technology w
Overall use factor	y^w	$\geq y_p^w \quad \forall p \in \mathbf{P}$ overall existence of technology w

selection, technical boundary conditions, and HEN cost estimations better representing the reality of industrial problems.

4.1 Benchmarking analysis

The selection of the benchmark cases was based on their recurrence in the literature, even though not many cases were treated repeatedly, and diversity in their characteristics. Suitable cases could not be identified in the most recent literature due to insufficient data provision in terms of process stream data, cost functions, or detailed heat pump configurations. The selected cases were each treated in several publications.

- Case *E2* was selected because it was treated in two consecutive studies by Shelton and Grossmann [23, 24] and due to its heating and cooling requirements which span over a continuous temperature range as shown in Figure 3(a). This case provides exploration potential of a multi-temperature, multi-stage heat pump system which crosses the pinch located at -8°C .
- An *ethylene plant* separation train [71] discussed by Colmenares and Seider [25] was chosen due to the refrigeration needs at extremely low temperatures (-115°C) as shown in Figure 3(b). The pinch point is located at approximately 130°C , which leaves little room for a heat pump crossing the pinch. Vaidyaraman and Maranas [30] discussed a slightly modified version of the same problem (different $\Delta T_{\min}$) with higher total cost, which is not treated here.

- (c) A *Cold Tray* distillation sequence presented by Colmenares and Seider [31] and later studied by Swaney [53] was selected to revisit the original solution which disregarded an obvious improvement of heat pumping across the process pinch (≈ 60 °C). Figure 3(c) shows the process temperature enthalpy profile indicating the process thermal demands and pinch point. Swaney [53] considered a solution with heat pumping across the process pinch for this case study, however with modified input data (isentropic compressor efficiency of 0.8) and is, therefore, not considered here.

The literature optimal cases were reproduced by adding constraints at the slave level of the HPS to force the resulting heat pump layout to contain the same features and operating conditions as those presented in the literature. This was achieved by pre-selecting temperature levels and fixing the active compressor stages and fluids. In this way, the HPS flexibility was tested and reference values for later comparison were calculated, given that most literature studies used different thermodynamic property calculations.

An analysis of the original and the reproduced data (referred to as *Reference* since they serve for later comparison) is presented in Table 5. The results are compared based on the TAC which was the objective function in the literature. It was observed that the results from literature cases *E2* and *Cold Tray* could be reproduced with a negligible difference (below $\pm 1\%$) in each of the categories including the TAC. The slight difference in results is explained by different property calculation methods. Reproduction of the *Ethylene* case generated around 23% higher electricity consumption which resulted in 22% higher TAC. The thermodynamic conditions are quite extreme (very low temperature) and thus advanced property estimations are necessary. The literature case consists of five cascaded heat pump cycles over a wide temperature range. Even small underestimation or overestimation of the electricity consumption in the lower cycles is therefore cascaded over the entire range. This, in combination with the property estimation methods, could explain the discrepancy.

4.2 Optimization

In this section, the generic HPS and multi-objective solution strategy were applied to the three literature cases. Parameters of the master level optimization are presented in appendix A.2. The MOGA algorithm was terminated after 10^5 function evaluations if the convergence criterion of 0.1 percent change in the non-dominated frontier was not reached. Multi-objective optimization

Figure 3: Grand composite curves (temperature enthalpy profiles) from process thermal streams of three benchmark cases, reproduced from (a) Shelton and Grossmann [24], (b) Lincoff et al. [71], (c) Colmenares and Seider [31], respectively.

Table 5: Comparison of original data and data reproduced (Reference) in this work with the HPS. A detailed description of the parameters is presented in Appendix B.1.

			<i>E2</i>			<i>Ethylene</i>			<i>Cold Tray</i>		
			Original [23]	Reference	Δ	Original [25]	Reference	Δ	Original [31]	Reference	Δ
Opex											
Cooling water	\$/y	0	0	-		23'950	25'020	4.5%	29'950	29'930	-0.1%
Steam	\$/y	10'440	10'460	0.2%	-	-	-	-	287'100	287'090	0.0%
Electricity	\$/y	27'370	27'620	0.9%	266'080	327'580	23.1%		97'260	96'370	-0.9%
Capex											
Compressors	\$/y	54'370	54'710	0.6%	188'990	230'810	22.1%		56'880	56'380	-0.9%
TAC	\$/y	92'180	92'790	0.7%	479'020	583'410	21.8%		471'190	469'770	-0.3%

was carried out with regard to the two competing objectives being the opex and capex. The saturation temperature levels and sub-cooling temperature differences (only in case *E2*) were the variables at the master level. Due to the more or less constant temperature requirements in the *Ethylene* and *Cold Tray* case studies, liquid subcooling and gas-cooling were not considered here. However, for these two cases, fluid selection was considered following the data from the literature [25, 31]. To investigate the potential for cascaded cycles, the set of candidate fluids was added at the slave level.

Input data and variable boundaries to the different cases are presented in appendix B.1. Figures 4(a),5(a),6(a) show the results from the multi-objective optimization. The minimum TAC point of each case was selected and compared to the Reference case in an integrated temperature enthalpy diagram in Figures 4(b),5(b),6(b) in addition to the flowcharts in Figure 7. The three cases are each discussed in the next paragraphs.

Temperature ranges, *E2* The multi-objective results in Figure 4(a) exhibit a pattern of diagonal lines with interstitial gaps. These lines can be explained by the differing numbers of compressors. A trade-off is constituted between a reduction of opex by multi-stage compression, and an increase in capex related to a higher number of compressors with their associated variable and fixed investment costs. The number of compressors for solutions in the non-dominated frontier between opex and capex ranges from three to six. Minimum TAC was achieved with four compressors in contrast to the six suggested in the Reference. One additional advantage of this multi-objective optimization approach is also that sub-optimal solutions with lower system complexity can be identified. The best solution with three compressors e.g. bears similar TAC ($< +1\%$) as the overall minimum cost solution with four compressors and may therefore be a better solution from the practical perspective. The HPS allows for a comprehensive analysis of heat pump features and operating conditions. The proposed minimum TAC solution consists of a heat pump with inter-cooling, subcooling, and gas-cooling heat exchangers as depicted in Figure 4(b) and Figure 7(a) which contribute to achieving similar performance (in terms of opex) at reduced compressor fixed costs capex compared to the Reference. This leads to a potential overall 5% reduction in TAC as displayed in Table 6.

Cascaded cycles, *Ethylene separation train* Results from the multi-objective optimization in Figure 5(a) show that the two objective functions, opex and capex, are not conflicting. Two main reasons were identified: (1) Due to the elevated process pinch point at 130°C, a pinch-crossing heat pump (as presented in case *E2*) is not feasible, thus there is no trade-off between (higher) compressor investment (capex) and (lower) hot utility requirements (opex); (2) The fixed investment costs of the compressors are distinctly smaller than the proportional costs which translates to the heat pump capex depending primarily on the electricity consumption (opex). Thus all objectives point in the same direction, which would make a Single Objec-

Figure 4: *E2*. (a) Multi-objective results, (b) integrated composite curves (Carnot factor enthalpy profiles) of Reference and min(HPS). Termination: 100k iterations (961 generations); last 50'000 iterations displayed.

Figure 5: *Ethylene*. (a) Multi-objective results, (b) integrated composite curves. Termination: 118 generations; all 2'852 iterations displayed.

Figure 6: *Cold Tray*. (a) Multi-objective results, (b) integrated composite curves. Termination: 100k iterations (229 generations); last 50'000 iterations displayed.

tive Genetic Algorithm (SOGA) [65] more appropriate. Running SOGA led to an equivalent result. The minimum point reveals an approximate 30% reduction in the TAC compared to the Reference (shown in Table 6) driven by the drastically diminished electricity consumption. As illustrated in Figure 5(b) and Figure 7(b), the power consumption was reduced due to a decrease in number of refrigerant switches from four to one, which avoided the minimum temperature difference ($DT_{\min} = 10$ K) in the switching heat exchangers. Inter-cooling at three levels (174.5 K, 189.5 K, 208.5 K) additionally improved the refrigerator performance leading to an improvement of the COP from 1.8 to 2.6. Due to the constraint on the compression ratio (unlike in the original) to be below 10, which may still be extremely high, the compressor is changed at 180.5 K. This leads to a more complicated, however, beneficial flow management to saturate the superheated compressor outlet.

Figure 7: Flowchart of the optimal HPS heat pump designs (a) *E2*, (b) *Ethylene*, (c) *Cold Tray* of benchmark analysis.

Table 6: Optimization results. Data shown as *Reference* was generated with HPS based on the respective literature input data (Section 4.1).

		<i>E2</i>		<i>Ethylene</i>		<i>Cold Tray</i>	
		Reference	min(HPS)	Reference	min(HPS)	Reference	min(HPS)
Opex							
Cooling water	\$/y	0	0	25,020	23,150	29,930	4,810
Steam	\$/y	10,460	10,370	0	0	287,090	39,310
Electricity	\$/y	27,620	28,040	327,580	223,340	96,370	189,900
Capex							
No. of compressors	#	6	4	5	5	3	5
Compressors	\$/y	54,710	49,630	230,810	159,140	56,380	109,220
TAC	\$/y	92,790	88,050	583,410	405,630	469,770	343,230
Improvement	%	0	5.1%	0%	30.5%	0%	26.9%
COP _{refrigeration}	-	4.4	4.3	1.8	2.6	5.3	5.8

Process pinch point, *Cold Tray distillation* Results from the multi-objective optimization in Figure 6(a) indicate a pattern of diagonal lines with gaps in between. Unlike case *E2* this is unrelated to the number of compressors in the system, which are mostly at their maximum (five) due to low compressor fix cost. However, it can be observed that the cooling water consumption correlates with the formation of lines. At highest opex, the largest amount of cooling water is consumed. It is used to cool the process and the refrigeration cycle as reported in the Reference displayed in Figure 6(b) and Figure 7(c). By adding a heat pump around the process pinch, the cooling water and hot utility consumptions were drastically reduced. The increase in capex is off-set by a larger decrease in opex leading to a maximum reduction of 27% in TAC in the best point, as depicted in Table 6. The HPS minimum TAC solution consists of two separate (ammonia based) heat pump systems, one satisfying the refrigeration needs (three compressors), and one across the process pinch (see Figure 7(c) and Figure 6(b), two compressors). With the refrigeration configuration a lower cost, higher COP solution could be derived compared to the reference case which consists of two separate heat pump cycles (R-22 (two compressors) and ammonia). The integrated composite curves in Figure 6(b) show that the HPS solution with the pinch heat pump not only reduces cost, but also exergy losses (proportional to the area between the curves) of the system.

Synthesis In conclusion, the HPS can represent a wide range of heat pump features and cycle architectures, while at the same time providing improved solutions to different literature optimal cases. This is attributed to a wider range of heat pump features considered and variable temperature level selection. As demonstrated, the level of complexity, variety of heat pump features considered, and technical constraints added depends on the choice of the user, which makes the superstructure flexible to handle. The solution strategy allows to generate a set of non-dominated solutions which enable the user to perform further analysis, thereby gaining deeper insight to the problem, and to apply other selection criteria. The literature cases discussed in this section serve for benchmarking the underlying approach, however, important criteria are neglected, such as HEN costs, compressor isentropic efficiencies, "real" utilities, and technical constraints thus generating "theoretical" solutions. In the next section 4.3, an extended version of the presented case *E2* is, therefore, discussed.

4.3 Extended analysis

The heat pump system for the extended case *E2* was optimized with respect to opex and capex assuming an isentropic compressor efficiency of 70%, a maximum compression ratio of 8 [bar/bar] in each compressor, and HEN cost estimation functions from the literature (section 3.3.1, Table 3). All input data is reported in appendix B.2.

4.3.1 Fluid selection

The choice of fluids considered for the extended case *E2* was based on the critical temperature ($T_{crit} \geq 40^\circ\text{C}$), the boiling point ($T_{boil} \leq -33^\circ\text{C}$), and the global warming potential ($\text{GWP} \leq 4 \cdot 10^3$). The fluid investment cost was not considered in this analysis. An interactive parallel coordinate visualization tool developed by Kermani et al. [72] was used to facilitate the fluid screening step which led to ten relevant fluids (see results in Figure 8a and Figure 14). Both fluid selection methods described in section 3.4 were applied and compared during this analysis. To ensure reasonable propagation of the MOGA algorithm during fluid selection at the slave level, a time limit of 600 seconds was imposed for the MILP solver. If the limit is reached, the solver returns the best integer solution at that point even if it is above the specified optimality gap. Nevertheless, a total of 25 000 MOGA iterations required higher computational time than 100 000 iterations with master level fluid selection.

Figure 8b shows the non-dominated frontiers of the different fluids generated over all MOGA iterations by both fluid selection methods. The results from the slave level selection (after intense computational effort) are dominated by the frontier of the master level selection, and it is thus concluded that if not necessary (e.g. for studying cascaded cycles) this method should be avoided. In the master level selection, propane dominates the other fluids over the entire range of solutions. This outcome was reproduced multiple times by rerunning MOGA with different seeds. Since the MOGA algorithm is aimed at improving the global non-dominated frontier, the frontier of propane yields a good approximation of the global Pareto curve for this

(a) Vapor-liquid saturation curves of selected fluids in temperature entropy diagram.

(b) Top: Selection at master level; 100k iterations, 211k sec. Bottom: Selection at slave level; 25k iterations, 890k sec.

Figure 8: (a) Fluid set and (b) multi-objective optimization results. In black: multi-fluid solution. R407c is not present, due to a Coolprop [56] problem with this fluid.

case. The minimum TAC solution generated a total reduction of approximately 9.5%. This solution consists of three compressors between -33 and 41.5°C with propane as working fluid (see Figure 15).

To study the dominance of propane over the other fluids, the minimum TAC solution was investigated more closely. Therefore, the fraction $\Delta Q^{\text{ref}}(T_2)/\Delta E^{\text{comp},2 \rightarrow 1}$ between evaporation enthalpy and compressor power amidst the two saturation temperature levels T_1 and T_2 of the first compressor was calculated for all fluids. Figure 9 shows the fraction versus the slope of the entropy vapor saturation curve $\Delta s/\Delta T = (s_v(T_1) - s_v(T_2))/(T_1 - T_2)$. Figure 9a reveals that the compression work correlates with the slope $\Delta s/\Delta T$. Propane is among the fluids which show the most isentropic behavior ($\Delta s/\Delta T \approx 0$) which leads to lower compression work and therefore a higher fraction $\Delta Q/\Delta E$. When calculating the fraction based on the enthalpy of a complete evaporation (as done in Figure 9a), propane is outperformed by r404a and r507a. In a real system, however, irreversibilities related to the expansion work will prevent complete evaporation. Accounting also for those irreversibilities, as shown in Figure 9b, propane yields the highest fraction $\Delta Q/\Delta E$ hence exhibiting ideal thermodynamic properties in this temperature range. Comparing the sequence of fluid frontiers (from Figure 8b, top) to the thermodynamic performance (Figure 9b) indicates a close agreement between thermodynamic and economic performance, which will be further investigated. The closest competitors to propane were: propylene, r161, r404a, r410a, and r507a. Ammonia and hydrogen sulfide generated higher-cost solutions, still strongly outperforming r41. All solutions (except r41) outperform the solution presented by the reference case updated with equivalent input data. The dominance of propane over the entire solution space agrees with other reports indicating superior performance in that temperature range [73]. Further fluid selection criteria could include safety factors (such as flammability or toxicity), fluid cost, ozone layer depletion potential (ODP), global warming potential (GWP) and heat transfer characteristics. Each of these criteria would favor different refrigerants and thus the filtering of potential solutions should be completed carefully to find the best solution for a given case.

(a) Complete evaporation.

(b) Incomplete evaporation, considering isenthalpic expansion from the level above (8 °C with 5K sub-cooling).

Figure 9: Compressor between saturation levels T_1 (32.5°C) and T_2 (-17°C).

4.3.2 COP, cycle complexity & HEN costs

Figure 10 illustrates the final non-dominated frontier of the results from the master level fluid selection including several properties of these solutions. The (cold) COP increases with decreasing opex, thus, reduced electricity consumption at increased number of compressors; the difference between the lowest (2.9) COP and highest (3.3) is achieved through a higher number of compression stages, increased subcooling and gas-cooling. The highest reduction in TAC (-9.5%) was achieved with opex of 49.9 k\$ (from Figure 8b, top). It can be further noted that the entire frontier spans a relatively small range of operating costs. This is attributed to the simple problem formulation of this benchmark case. In Figure 10, the expected inverse relationship between opex and HEN costs is clearly visible which is impacted by two main factors. The first factor relates to activation of gas-cooling. Since the heat transfer coefficients of gases are distinctly lower than those of condensing fluids, recuperation of sensible heat contained in superheated vapor requires more heat exchange area and therefore increases the HEN costs. The second factor increasing HEN cost is related to a higher number of compression stages, which implies installation of more heat exchangers; thus, influencing both opex and capex. It is also observed that the amount of subcooling increases in tandem with the COP thus providing another option for improving operational efficiency with increased investment. Subcooling was activated in the minimum TAC solution which indicates that its advantageous characteristics should not be overlooked in cycle design. A HEN design of the reference and minimum TAC case was conducted (as shown in B.2, Figure 16). The optimal solution requires one more heat exchanger than the reference case which is mildly penalized by the HEN cost function thereby being outweighed by the benefits of the reduced opex. The HEN cost estimation from the area targeting compares satisfactorily to the actual design with an overestimation between 8-11% (optimal case design: 53.6, estimation: 57.8 k\$/y; reference case design: 52.8, estimation: 58.8 k\$/y). Likewise compares the total estimated area and the minimum number of heat exchangers.

Figure 10: Overall non-dominated frontier of MOGA results from master level fluid selection.

5 Conclusions

This study has presented a mathematical approach for optimal design of industrial heat pumps spanning a wide variable solution space. The method provides a framework for deriving utility targets, including optimal heat pump component sizes and operating conditions. This provides a basis for detailed system design in a subsequent step to account for dynamics and off-design operation.

The novel superstructure-based synthesis method is embedded in a computational framework and is solved in a decomposition approach. A comprehensive list of heat pump features are taken into account while technical limitations are considered and a set of solutions is provided which allows for expert-based decision making and further in-depth analysis of the solutions.

For benchmarking, the method was compared to a set of literature cases generating between 5 and 30% cost improvements to the optimal solutions reported. An extended version of one case is presented considering fluid selection, HEN cost estimations, and technical constraints within the problem formulation. The extended case highlights a trade-off between energy efficiency and system complexity expressed by the increase of heat exchanger network costs with the number of compression stages, level of gas-cooling and subcooling which all improve the COP. This is especially evident when comparing the solutions with 3 and 5 compression stages causing an increase of the COP from 2.9 to 3.1 at 3% increase in TAC. Fluid selection was successfully performed indicating that propane is the most favorable fluid both in economic and thermodynamic terms in this temperature range. The HPS proves to be flexible for different requirements serving in a variety of cases. It has to be noted that a comprehensive analysis of an industrial process should always comprehend optimization of the entire utility network, including the hot utilities. This was neglected in this work to be in accordance with the literature input data. In subsequent analysis, the trade-off with other utility technologies should be considered. Future work should also include supercritical cycles, refined fluid and component selection strategies, as well as consideration of off-design performance in multi-time problems.

Acknowledgements

The authors acknowledge the support of Swiss Federal Office of Energy SFOE (Grant SI/501487-01). The research project was further financially supported by the Swiss Innovation Agency Innosuisse and is part of the Swiss Competence Center for Energy Research SCCER EIP - Efficiency of Industrial Processes.

References

- [1] IEA. Application of Industrial Heat Pumps: Executive Summary, 2014. URL <http://heatpumpingtechnologies.org/publications/application-of-industrial-heat-pumps-executive-summary/>.
- [2] K. J. Chua, S. K. Chou, and W. M. Yang. Advances in heat pump systems: A review. *Applied Energy*, 87(12):3611–3624, 2010. ISSN 0306-2619. doi: 10.1016/j.apenergy.2010.06.014. URL <http://www.sciencedirect.com/science/article/pii/S030626191000228X>.
- [3] H.J. Laue. Annex 35 Final Report - Application of Industrial Heat Pumps, Part 1. Technical report, IEA, 2014. URL <http://heatpumpingtechnologies.org/publications/application-of-industrial-heat-pumps-part-2/>.

- [4] Cordin Arpagaus, Frederic Bless, Jürg Schiffmann, and Stefan S. Bertsch. Multi-temperature heat pumps: A literature review. *International Journal of Refrigeration*, 69:437–465, September 2016. ISSN 0140-7007. doi: 10.1016/j.ijrefrig.2016.05.014. URL <http://www.sciencedirect.com/science/article/pii/S0140700716301190>.
- [5] Xudong Wang, Yunho Hwang, and Reinhard Radermacher. Two-stage heat pump system with vapor-injected scroll compressor using R410a as a refrigerant. *International Journal of Refrigeration*, 32(6):1442–1451, September 2009. ISSN 0140-7007. doi: 10.1016/j.ijrefrig.2009.03.004. URL <http://www.sciencedirect.com/science/article/pii/S0140700709000814>.
- [6] J. Schiffmann. Integrated Design and Multi-objective Optimization of a Single Stage Heat-Pump Turbocompressor. *Journal of Turbomachinery*, 137(7):071002–071002–9, July 2015. ISSN 0889-504X. doi: 10.1115/1.4029123. URL <http://dx.doi.org/10.1115/1.4029123>.
- [7] F.J. Barnés and C.J. King. Synthesis of cascade refrigeration and liquefaction systems. *Industrial and Engineering Chemistry: Process Design and Development*, 13(4):421–433, 1974. ISSN 0019-7882.
- [8] W.B. Cheng and R.S.H. Mah. Interactive synthesis of cascade refrigeration systems. *Industrial & Engineering Chemistry Process Design and Development*, 19(3):410–420, 1980. ISSN 0196-4305.
- [9] Bodo Linnhoff and John R. Flower. Synthesis of heat exchanger networks: I. Systematic generation of energy optimal networks. *AIChE Journal*, 24(4):633–642, July 1978. ISSN 1547-5905. doi: 10.1002/aic.690240411. URL <http://onlinelibrary.wiley.com/doi/10.1002/aic.690240411/abstract>.
- [10] Ian C. Kemp. *Pinch Analysis and Process Integration: A User Guide on Process Integration for the Efficient Use of Energy*. Butterworth-Heinemann, April 2011. ISBN 978-0-08-046826-6. Google-Books-ID: gQMxilJQmV4C.
- [11] D. W. Townsend and Bodo Linnhoff. Heat and power networks in process design. Part II: Design procedure for equipment selection and process matching. *AIChE Journal*, 29(5):748–771, September 1983. ISSN 1547-5905. doi: 10.1002/aic.690290509. URL <http://onlinelibrary.wiley.com/doi/10.1002/aic.690290509/abstract>.
- [12] Saidas M. Ranade. New insights on optimal integration of heat pumps in industrial sites. *Heat Recovery Systems and CHP*, 8(3):255–263, January 1988. ISSN 0890-4332. doi: 10.1016/0890-4332(88)90061-0. URL <http://www.sciencedirect.com/science/article/pii/0890433288900610>.
- [13] Michele Zehnder. Efficient air-water heat pumps for high temperature lift residential heating, including oil migration aspects. 2004. doi: 10.5075/epfl-thesis-2998,urn:nbn:ch:bel-epfl-thesis2998-6. URL <https://infoscience.epfl.ch/record/33470>.
- [14] H. Sato, Y. Kimata, Y. Hotta, T. Goto, H. Mizuno, and H. Kobayashi. Development of two-stage compressor for CO₂ heat-pump water heaters. *Mitsubishi Heavy Ind Tech Rev*, 49:92–97, 2012.
- [15] Wilbert F. Stoecker. *Industrial refrigeration handbook*. McGraw-Hill, New York, vol 10 edition, 1998. URL <http://library.wur.nl/WebQuery/clc/977739>.

- [16] Tomoichiro Tamura, Yuuichi Yakumaru, and Fumitoshi Nishiwaki. Experimental study on automotive cooling and heating air conditioning system using CO₂ as a refrigerant. *International Journal of Refrigeration*, 28(8):1302–1307, 2005. ISSN 0140-7007. doi: 10.1016/j.ijrefrig.2005.09.010. URL <http://www.sciencedirect.com/science/article/pii/S0140700705001829>.
- [17] Matej Visek, Cesare Maria Joppolo, Luca Molinaroli, and Andrea Olivani. Advanced sequential dual evaporator domestic refrigerator/freezer: System energy optimization. *International Journal of Refrigeration*, 43:71–79, July 2014. ISSN 0140-7007. doi: 10.1016/j.ijrefrig.2014.03.001. URL <http://www.sciencedirect.com/science/article/pii/S0140700714000486>.
- [18] Chieko Kondou and Shigeru Koyama. Thermodynamic Assessment of High-Temperature Heat Pumps for Heat Recovery. *International Refrigeration and Air Conditioning Conference*, January 2014. URL <http://docs.lib.purdue.edu/iracc/1408>.
- [19] Petter Neksa, Håvard Rekstad, G. Reza Zakeri, and Per Arne Schiefloe. CO₂-heat pump water heater: characteristics, system design and experimental results. *International Journal of Refrigeration*, 21(3):172–179, 1998. ISSN 0140-7007. doi: 10.1016/S0140-7007(98)00017-6. URL <http://www.sciencedirect.com/science/article/pii/S0140700798000176>.
- [20] M. Elakdhar, E. Nehdi, and L. Kairouani. Analysis of a Compression/Ejection Cycle for Domestic Refrigeration. *Industrial & Engineering Chemistry Research*, 46(13):4639–4644, June 2007. ISSN 0888-5885. doi: 10.1021/ie070377e. URL <http://dx.doi.org/10.1021/ie070377e>.
- [21] Hiroshi Oshitani, Yasushi Yamanaka, Hirotugu Takeuchi, Katsuya Kusano, Makoto Ikegami, Yoshiaki Takano, Naohisa Ishizaka, and Takayuki Sugiura. Vapor compression cycle having ejector. Patent US7254961 B2, August 2007. URL <http://www.google.com/patents/US7254961>.
- [22] Hiroshi Oshitani, Hirotugu Takeuchi, Etsuhisa Yamada, and Haruyuki Nishijima. Ejector-type refrigerant cycle device. Patent US8186180 B2, May 2012. URL <http://www.google.ch/patents/US8186180>.
- [23] M. R. Shelton and I. E. Grossmann. Optimal synthesis of integrated refrigeration systems I. Mixed-integer programming model. *Computers & Chemical Engineering*, 10(5):445–459, January 1986. ISSN 0098-1354. doi: 10.1016/0098-1354(86)85014-1. URL <http://www.sciencedirect.com/science/article/pii/0098135486850141>.
- [24] M. R. Shelton and I. E. Grossmann. Optimal synthesis of integrated refrigeration systems II. Implicit enumeration scheme. *Computers & Chemical Engineering*, 10(5):461–477, January 1986. ISSN 0098-1354. doi: 10.1016/0098-1354(86)85015-3. URL <http://www.sciencedirect.com/science/article/pii/0098135486850153>.
- [25] T. R. Colmenares and W. D. Seider. Synthesis of cascade refrigeration systems integrated with chemical processes. *Computers & Chemical Engineering*, 13(3):247–258, 1989. ISSN 0098-1354. doi: 10.1016/0098-1354(89)85002-1. URL <http://www.sciencedirect.com/science/article/pii/0098135489850021>.

- [26] Audun Aspelund, David Olsson Berstad, and Truls Gundersen. An Extended Pinch Analysis and Design procedure utilizing pressure based exergy for subambient cooling. *Applied Thermal Engineering*, 27(16):2633–2649, November 2007. ISSN 1359-4311. doi: 10.1016/j.applthermaleng.2007.04.017. URL <http://www.sciencedirect.com/science/article/pii/S1359431107001627>.
- [27] Helen Carla Becker. *Methodology and Thermo-Economic Optimization for Integration of Industrial Heat Pumps*. PhD thesis, 2012.
- [28] Gbemi Oluleye, Megan Jobson, Robin Smith, and Simon J. Perry. Evaluating the potential of process sites for waste heat recovery. *Applied Energy*, 161:627–646, January 2016. ISSN 0306-2619. doi: 10.1016/j.apenergy.2015.07.011. URL <http://www.sciencedirect.com/science/article/pii/S0306261915008405>.
- [29] Meysam Kamalinejad, Majid Amidpour, and S. M. Mousavi Naeynian. Thermodynamic design of a cascade refrigeration system of liquefied natural gas by applying mixed integer non-linear programming. *Chinese Journal of Chemical Engineering*, 23(6):998–1008, June 2015. ISSN 1004-9541. doi: 10.1016/j.cjche.2014.05.023. URL [//www.sciencedirect.com/science/article/pii/S1004954115000397](http://www.sciencedirect.com/science/article/pii/S1004954115000397).
- [30] Shankar Vaidyaraman and Costas D. Maranas. Optimal synthesis of refrigeration cycles and selection of refrigerants. *AIChE Journal*, 45(5):997–1017, 1999. ISSN 1547-5905. doi: 10.1002/aic.690450510. URL <http://onlinelibrary.wiley.com/doi/10.1002/aic.690450510/abstract>.
- [31] T. R. Colmenares and W. D. Seider. Heat and power integration of chemical processes. *AIChE Journal*, 33(6):898–915, June 1987. ISSN 1547-5905. doi: 10.1002/aic.690330604. URL <http://onlinelibrary.wiley.com/doi/10.1002/aic.690330604/abstract>.
- [32] Anna S. Wallerand, Maziar Kermani, Régis Voillat, Ivan Kantor, and François Maréchal. Optimal design of solar-assisted industrial processes considering heat pumping: Case study of a dairy. *Renewable Energy*, July 2017. ISSN 0960-1481. doi: 10.1016/j.renene.2017.07.027. URL <http://www.sciencedirect.com/science/article/pii/S0960148117306390>.
- [33] Anna S. Wallerand, Maziar Kermani, Ivan D. Kantor, and François Maréchal. General Superstructure Synthesis and Bi-level Solution Strategy for Industrial Heat Pumping. In Antonio Espuña, Moisès Graells, and Luis Puigjaner, editors, *27th European Symposium on Computer Aided Process Engineering*, volume 40 of *Computer Aided Chemical Engineering*, pages 1159 – 1164. Elsevier, 2017. URL <http://www.sciencedirect.com/science/article/pii/B9780444639653501951>. DOI: 10.1016/B978-0-444-63965-3.50195-1.
- [34] B. J. Zhang, Z. L. Zhang, K. Liu, and Q. L. Chen. Network Modeling and Design for Low Grade Heat Recovery, Refrigeration, and Utilization in Industrial Parks. *Industrial & Engineering Chemistry Research*, 55(36):9725–9737, September 2016. ISSN 0888-5885. doi: 10.1021/acs.iecr.6b02033. URL <http://dx.doi.org/10.1021/acs.iecr.6b02033>.
- [35] Gbemi Oluleye, Robin Smith, and Megan Jobson. Modelling and screening heat pump options for the exploitation of low grade waste heat in process sites. *Applied Energy*, 169:267–286, 2016. ISSN 0306-2619. doi: 10.1016/j.apenergy.2016.02.015. URL <http://www.sciencedirect.com/science/article/pii/S0306261916301386>.
- [36] Gbemi Oluleye, Megan Jobson, and Robin Smith. Process integration of waste heat upgrading technologies. *Process Safety and Environmental Protection*, 103, Part B:

- 315–333, September 2016. ISSN 0957-5820. doi: 10.1016/j.psep.2016.02.003. URL <http://www.sciencedirect.com/science/article/pii/S0957582016000306>.
- [37] Ha Dinh, Jian Zhang, and Qiang Xu. Process synthesis for cascade refrigeration system based on exergy analysis. *AIChE Journal*, 61(8):2471–2488, August 2015. ISSN 1547-5905. doi: 10.1002/aic.14843. URL <http://onlinelibrary.wiley.com/doi/10.1002/aic.14843/abstract>.
 - [38] Guilian Liu, Hua Zhou, Renjie Shen, and Xiao Feng. A graphical method for integrating work exchange network. *Applied Energy*, 114:588–599, February 2014. ISSN 0306-2619. doi: 10.1016/j.apenergy.2013.10.023. URL <http://www.sciencedirect.com/science/article/pii/S030626191300843X>.
 - [39] Mohd Shariq Khan and Moonyong Lee. Design optimization of single mixed refrigerant natural gas liquefaction process using the particle swarm paradigm with nonlinear constraints. *Energy*, 49:146–155, January 2013. ISSN 0360-5442. doi: 10.1016/j.energy.2012.11.028. URL <http://www.sciencedirect.com/science/article/pii/S0360544212008894>.
 - [40] Roman Hackl and Simon Harvey. Applying exergy and total site analysis for targeting refrigeration shaft power in industrial clusters. *Energy*, 55:5–14, June 2013. ISSN 0360-5442. doi: 10.1016/j.energy.2013.03.029. URL <http://www.sciencedirect.com/science/article/pii/S036054421300217X>.
 - [41] Helen Becker and François Maréchal. Targeting industrial heat pump integration in multi-period problems. In Iftekhar A. Karimi and Rajagopalan Srinivasan, editor, *Computer Aided Chemical Engineering*, volume 31 of *11th International Symposium on Process Systems Engineering*, pages 415–419. Elsevier, 2012. URL <http://www.sciencedirect.com/science/article/pii/B9780444595072500755>.
 - [42] Jian Zhang and Qiang Xu. Cascade refrigeration system synthesis based on exergy analysis. *Computers & Chemical Engineering*, 35(9):1901–1914, September 2011. ISSN 0098-1354. doi: 10.1016/j.compchemeng.2011.02.015. URL <http://www.sciencedirect.com/science/article/pii/S0098135411000779>.
 - [43] M. M. Faruque Hasan, Md. Shamsuzzaman Razib, and I. A. Karimi. Optimization of Compressor Networks in LNG Operations. In Caludio Augusto Oller do Nascimento and Evaristo Chalbaud Biscaia Rita Maria de Brito Alves, editor, *Computer Aided Chemical Engineering*, volume 27 of *10th International Symposium on Process Systems Engineering: Part A*, pages 1767–1772. Elsevier, 2009. URL <http://www.sciencedirect.com/science/article/pii/S1570794609706856>. DOI: 10.1016/S1570-7946(09)70685-6.
 - [44] Frank Del Nogal, Jin-Kuk Kim, Simon Perry, and Robin Smith. Optimal Design of Mixed Refrigerant Cycles. *Industrial & Engineering Chemistry Research*, 47(22):8724–8740, November 2008. ISSN 0888-5885. doi: 10.1021/ie800515u. URL <http://dx.doi.org/10.1021/ie800515u>.
 - [45] Miguel J. Bagajewicz and Andres F. Barbaro. On the use of heat pumps in total site heat integration. *Computers & Chemical Engineering*, 27(11):1707–1719, November 2003. ISSN 0098-1354. doi: 10.1016/S0098-1354(03)00149-2. URL <http://www.sciencedirect.com/science/article/pii/S0098135403001492>.
 - [46] Konstantinos Holiastos and Vasilios Manousiouthakis. Minimum hot/cold/electric utility cost for heat exchange networks. *Computers & Chemical Engineering*, 26(1):3–16,

- January 2002. ISSN 0098-1354. doi: 10.1016/S0098-1354(01)00726-8. URL <http://www.sciencedirect.com/science/article/pii/S0098135401007268>.
- [47] Shankar Vaidyaraman and Costas D. Maranas. Synthesis of Mixed Refrigerant Cascade Cycles. *Chemical Engineering Communications*, 189(8):1057–1078, August 2002. ISSN 0098-6445. doi: 10.1080/00986440213475. URL <http://dx.doi.org/10.1080/00986440213475>.
 - [48] F. Maréchal and B. Kalitventzeff. A tool for optimal synthesis of industrial refrigeration systems. In Rafiqul Gani and Sten Bay Jorgensen, editor, *Computer Aided Chemical Engineering*, volume 9 of *European Symposium on Computer Aided Process Engineering - 1134th European Symposium of the Working Party on Computer Aided Process Engineering*, pages 457–462. Elsevier, 2001. URL <http://www.sciencedirect.com/science/article/pii/S1570794601800717>.
 - [49] Thomas E Daubert. Physical and thermodynamic properties of pure chemicals: data compilation. *Design Institute for Physacal Property Data (DIPPR)*, 1989.
 - [50] Friedrich Kauf. Determination of the optimum high pressure for transcritical CO₂-refrigeration cycles. *International Journal of Thermal Sciences*, 38(4):325–330, April 1999. ISSN 1290-0729. doi: 10.1016/S1290-0729(99)80098-2. URL <http://www.sciencedirect.com/science/article/pii/S1290072999800982>.
 - [51] Erik Wallin and Thore Berntsson. Integration of heat pumps in industrial processes. *Heat Recovery Systems and CHP*, 14(3):287–296, May 1994. ISSN 0890-4332. doi: 10.1016/0890-4332(94)90024-8. URL <http://www.sciencedirect.com/science/article/pii/0890433294900248>.
 - [52] B. Linnhoff and V. R. Dhole. Shaftwork targets for low-temperature process design. *Chemical Engineering Science*, 47(8):2081–2091, June 1992. ISSN 0009-2509. doi: 10.1016/0009-2509(92)80324-6. URL <http://www.sciencedirect.com/science/article/pii/0009250992803246>.
 - [53] Ross E. Swaney. Thermal integration of processes with heat engines and heat pumps. *AIChE Journal*, 35(6):1003–1016, June 1989. ISSN 1547-5905. doi: 10.1002/aic.690350614. URL <http://onlinelibrary.wiley.com/doi/10.1002/aic.690350614/abstract>.
 - [54] Mark R. Shelton and Ignacio E. Grossmann. A shortcut procedure for refrigeration systems. *Computers & Chemical Engineering*, 9(6):615–619, January 1985. ISSN 0098-1354. doi: 10.1016/0098-1354(85)87017-4. URL <http://www.sciencedirect.com/science/article/pii/0098135485870174>.
 - [55] B. Linnhoff and E. Hindmarsh. The pinch design method for heat exchanger networks. *Chemical Engineering Science*, 38(5):745–763, January 1983. ISSN 0009-2509. doi: 10.1016/0009-2509(83)80185-7. URL <http://www.sciencedirect.com/science/article/pii/0009250983801857>.
 - [56] *CoolProp*. www.coolprop.org, Online; accessed 11-02-2016.
 - [57] E.W. Lemmon, M.L. Huber, and M.O. McLinden. NIST Standard Reference Database 23: Reference Fluid Thermodynamic and Transport Properties-REFPROP. Standard Reference Data Program Version 9.1, National Institute of Standards and Technology, Gaithersburg, 2013.

- [58] Giorgio Soave. Equilibrium constants from a modified Redlich-Kwong equation of state. *Chemical Engineering Science*, 27(6):1197–1203, June 1972. ISSN 0009-2509. doi: 10.1016/0009-2509(72)80096-4. URL <http://www.sciencedirect.com/science/article/pii/0009250972800964>.
- [59] J. Pongo, W. Boras, R. Schacter, K. Hanson, C. Lowe, and J. Forrest. HYSYS-Reference. Technical Report Vol. 1, 2, Hyprotech Ltd., 1996.
- [60] Ding-Yu Peng and Donald B Robinson. A new two-constant equation of state. *Industrial & Engineering Chemistry Fundamentals*, 15(1):59–64, 1976.
- [61] M.N. Dumont and B. Kalitventzeff. BELSIM Vali H users manual. Technical report, Belsim SA, 1995.
- [62] Céline Weber, François Maréchal, and Daniel Favrat. Design and optimization of district energy systems. In Valentin Plesu and Paul Serban Agachi, editor, *Computer Aided Chemical Engineering*, volume 24 of *17th European Symposium on Computer Aided Process Engineering*, pages 1127–1132. Elsevier, 2007. URL <http://www.sciencedirect.com/science/article/pii/S1570794607802124>.
- [63] Min-Jung Yoo, Lindsay Lessard, Maziar Kermani, and Francois Marechal. OsmoseLua - An Integrated Approach to Energy Systems Integration with LCIA and GIS. In Kv Ger-naey, Jk Huusom, and R Gani, editors, *12Th International Symposium On Process Systems Engineering (Pse) And 25Th European Symposium On Computer Aided Process Engineering (Escape), Pt A*, volume 37 of *Computer Aided Chemical Engineering*, pages 587–592, Amsterdam, 2015. Elsevier Science Bv. ISBN 978-0-444-63578-5.
- [64] B.M. Adams, L.E. Bauman, W.J. Bohnhoff, K.R. Dalbey, M.S. Ebeida, J.P. Eddy, M.S. Eldred, P.D. Hough, K.T. Hu, J.D. Jakeman, J.A. Stephens, L.P. Swiler, D.M. Vigil, and T.M. Wildey. Dakota, A Multilevel Parallel Object-Oriented Framework for Design Optimization, Parameter Estimation, Uncertainty Quantification, and Sensitivity Analysis: Version 6.0 User Manual. Technical report, July 2014. URL <https://dakota.sandia.gov/documentation.html>.
- [65] J.E. Eddy and K. Lewis. Effective generation of pareto sets using genetic programming. In *Proceedings of ASME Design Engineering Technical Conference*, Pittsburgh, Pennsylvania, 2001.
- [66] DW Townsend and B Linnhoff. Surface area targets for heat exchanger networks. In *ICHEME Annual Research Meeting, Bath, UK*, 1984.
- [67] Bodo Linnhoff, David R. Mason, and Ian Wardle. Understanding heat exchanger networks. *Computers & Chemical Engineering*, 3(1–4):295–302, 1979. ISSN 0098-1354. doi: 10.1016/0098-1354(79)80049-6. URL <http://www.sciencedirect.com/science/article/pii/0098135479800496>.
- [68] François Maréchal and Boris Kalitventzeff. Targeting the integration of multi-period utility systems for site scale process integration. *Applied Thermal Engineering*, 23(14): 1763–1784, 2003. ISSN 1359-4311. doi: 10.1016/S1359-4311(03)00142-X. URL <http://www.sciencedirect.com/science/article/pii/S135943110300142X>.
- [69] Robert Fourer, David M. Gay, and Brian W. Kernighan. *AMPL: A Modeling Language for Mathematical Programming*. Duxbury Press / Brooks/Cole Publishing Company, 2003. ISBN ISBN 0-534-38809-4.

- [70] IBM ILOG CPLEX Optimization Studio V12.7.0 documentation, February 2015. URL http://www.ibm.com/support/knowledgecenter/SSSA5P_12.7.0/ilog.odms.studio.help/Optimization_Studio/topics/COS_intro_features.html.
- [71] AM Lincoff, IE Grossmann, and GE Blau. Separation System for Recovery of Ethylene and Light Products from Naphtha-Pyrolysis Gas Stream. *Process Design Case Study*, 1985.
- [72] Maziar Kermani, Anna S. Wallerand, Ivan D. Kantor, and François Maréchal. Generic superstructure synthesis of organic Rankine cycles for waste heat recovery in industrial processes. *Applied Energy*, 212:1203–1225, February 2018. ISSN 0306-2619. doi: 10.1016/j.apenergy.2017.12.094. URL <http://www.sciencedirect.com/science/article/pii/S0306261917318172>.
- [73] Y. S Chang, M. S Kim, and S. T Ro. Performance and heat transfer characteristics of hydrocarbon refrigerants in a heat pump system. *International Journal of Refrigeration*, 23(3):232–242, May 2000. ISSN 0140-7007. doi: 10.1016/S0140-7007(99)00042-0. URL <http://www.sciencedirect.com/science/article/pii/S0140700799000420>.
- [74] Huijuan Chen, D. Yogi Goswami, and Elias K. Stefanakos. A review of thermodynamic cycles and working fluids for the conversion of low-grade heat. *Renewable and sustainable energy reviews*, 14(9):3059–3067, 2010.
- [75] T. C. Hung, T. Y. Shai, and S. K. Wang. A review of organic rankine cycles (ORCs) for the recovery of low-grade waste heat. *Energy*, 22(7):661–667, July 1997. ISSN 0360-5442. doi: 10.1016/S0360-5442(96)00165-X. URL <http://www.sciencedirect.com/science/article/pii/S036054429600165X>.
- [76] Lon E. Bell. Cooling, heating, generating power, and recovering waste heat with thermoelectric systems. *Science*, 321(5895):1457–1461, 2008.
- [77] Web of Science [v.5.25.1] - Web of Science Core Collection Home, August 2017. URL https://apps.webofknowledge.com/WOS_GeneralSearch_input.do?product=WOS&search_mode=GeneralSearch&SID=R2JaAJG1qMrpvtvJbFY&preferencesSaved=.
- [78] Chao Fu and Truls Gundersen. A Novel Sensible Heat Pump Scheme for Industrial Heat Recovery. *Industrial & Engineering Chemistry Research*, 55(4):967–977, February 2016. ISSN 0888-5885. doi: 10.1021/acs.iecr.5b02417. URL <http://dx.doi.org/10.1021/acs.iecr.5b02417>.
- [79] Linde Group. Refrigerants Environmental Data. Ozone Depletion and Global Warming Potential. URL http://www.linde-gas.com/internet.global.lindegas.global/en/images/Refrigerants%20environmental%20GWPs17_111483.pdf.
- [80] Jo Gwanggon, Amin Kalantarifard, Jang Jihoon, Byeon Eunsong, Jang Yuna, and Yang Gosu. The effects of malodorous substances from Municipal Solid Waste (MSW) to Climate-Change as Greenhouse-Gas: Calculating GWP of Hydrogen Sulfide. Japan, 2015. URL https://www.jstage.jst.go.jp/article/jsmcwm/26/0/26_547/_pdf.
- [81] Kalpesh N. Kothale, Kundlik V. Mali, and S.D. Nimbalkar. Study of R-161 refrigerant as an Alternate Refrigerant to various other refrigerants. In *PRESSCO IJCET Special Issue - 4*, Pune, India, March 2016. MIT College of Engineering. ISBN E - ISSN 2277 – 4106. URL <http://inpressco.com/category/ijcet>.

- [82] Nicholas Cox, Victor Mazur, and Daniel Colbourne. New High Pressure Low-G WP Azeotropic and Near-Azeotropic Refrigerant Blends. Purdue, 2008. URL <http://docs.lib.purdue.edu/iracc/987>.
- [83] Aspen Energy Analyzer. Energy Management Software - Energy Optimization |. URL <http://aspentech.com/products/engineering/aspen-energy-analyzer/>.

A General

A.1 Literature review & heat pump systems

Analysis of the most cited publications during the past 10 years related to the key word *waste heat recovery*, demonstrates a dominance of studies dealing with ORC [74, 75] and thermoelectric devices [76], while the contributions related to heat pump and refrigeration applications are negligible. Figure 11 illustrates the distribution of the most cited publications within the last 10 years with an average citation of more or equal to five per year. This added up to 158 publications.

Figure 11: Web of science [77], key words: *waste heat recovery*, top cited papers of last 10 years (≥ 5 citations/year), accessed 11.08.2017.

Figure 12 shows the temperature enthalpy diagrams of processes (A) and (B). Process (A) has a sharp pinch point with a small temperature lift. While process (B) shows a smooth pinch point with heating and cooling requirements spanning over a range of temperatures. Integration of different mechanical heat pump systems are illustrated, starting from a single-stage, single fluid (inversed Rankine cycle) heat pump in Figure 12-(A) and (B); multi-stage, single fluid heat pumping is shown in Figure 12-(1B); single-stage, multi fluid (zeotropic mixture) is depicted in Figure 12-(2B); and a single-stage, single fluid inverse Brayton heat pump is illustrated in Figure 12-(3B). Single fluid (inverse Rankine) heat pumps can satisfy constant temperature thermal requirements (single-stage) as well as continuous temperature ranges with help of multi-stage cycles at a reasonable COP. In generating a temperature glide, zeotropic mixtures [44, 47] or heat pumps relying on the inverse Brayton cycle [78] may be advantageous for demands spanning wide temperature ranges, but less flexible e.g. with regards to constant temperature requirements. Therefore, this work is focused on the first three figures Figure 12-(A-1B).

Figure 12: Temperature enthalpy diagram of process (A) and (B) with single-stage heat pump across process pinch point. (1B) multi-stage, single fluid inverse Rankine heat pump, (2B) single-stage, zeotropic fluid mixture inverse Rankine heat pump, (3B) single-stage, single fluid inverse Brayton heat pump.

A.2 MOGA input parameters

All computations were conducted on a machine with 8-Core Xeon 2.4 GHz processor with 16.0 GB of RAM. Table 7 depicts the data used in the multi-objective genetic algorithm (MOGA [65]) from the Dakota package [64]. Different parameters were used during different runs. Due to danger of getting trapped in local minima, especially during the extended analysis (in section 4.3) with fluid selection at the master level, the mutation and crossover parameters were set more aggressively. These parameters were selected based on a heuristic analysis tracking the propagation of the non-dominated frontier. Figure 13 shows the propagation of MOGA and the dominance of each population over the previous indicating that a total of 10^5 evaluations achieve satisfying convergence.

Table 7: Input parameters for MOGA method [65].

Parameter	Expression	Value	Comment
Initial population	population_size	300, 500	initial set of individuals (section 4.2, 4.3)
Crossover type	crossover_type	'shuffle_random'	(section 4.2) select one of each design var. of the parents for child
		'multi_point_binary 2'	(section 4.3) bit switching at 2 pnts. in the binary encoded genome of two parents
Crossover rate	crossover_rate	0.9	crossover rate of new generation
Mutation type	mutation_type	'replace_uniform', 'bit_random'	(section 4.2) randomly choosing variable and reassigning it to a random valid value (section 4.3) flips a randomly chosen bit in the string of randomly chosen variable
Mutation rate	mutation_rate	0.1, 0.2	(section 4.2, 4.3)
Maximum iteration	max_iterations	100, 200 10^3	maximum number of iteration unless convergence is reached (section 4.2, 4.3)
Convergence type	convergence_type	'average_fitness_tracker'	
Percent change	percent_change	0.1	(default) percent change in non-dominated frontier

A.3 MILP input parameters

The input parameters used for CPLEX [70] are displayed in Table 8. The last three entries were found based on the parameter tuning performed by CPLEX.

Table 8: Input parameters for CPLEX [70], AMPL [69].

Parameter	Expression	Value	Comment
mipgap	'mipgap'	0.001	relative difference between best integer and best bound
time	'time'	300, 600	cpu time limit in seconds (all, case S)
flow cuts	'flowcuts'	1	(agressive) use of flow cuts in solving MIPs
mir cuts	'mircuts'	1	(moderate) generation of MIP rounding cuts
branch	'branch'	1	branching direction for integer variables

Figure 13: Analysis of MOGA propagation including non-dominated frontier in 10^5 evaluations of extended case *E2*, master level fluid selection.

B Input data

B.1 Benchmark cases

The thermal streams considered in the different benchmark cases are depicted in the original source and were reproduced in Table 9. The objective functions, variables, boundary conditions, and input data to the respective optimization problems are displayed in Table 10. The HEN costs were disregarded during this optimization following the literature input data.

In case *E2*, gas-cooling was considered. It has to be noted that the temperature difference below which gas-cooling was realised was not selected as a variable. It was set to the difference between the temperature level i and the one above ($i - 1$), yielding $\Delta T_{i,DSH} = T_{i-1} - T_i$. The main effect of this choice is ensuring that the generated solutions do not require splitting of the gas-cooling thermal streams, in other words, they do not require several heat exchangers cooling gas at one compressor outlet.

Table 9: Streams data of the three benchmark cases.

(a) <i>E2</i> [23]					(b) <i>Ethylene</i> [25]					(c) <i>Cold Tray</i> [31]				
Stream name	T_{in} K	T_{out} K	ΔQ kW/K	α kW/m ² K	Stream name	T_{in} K	T_{out} K	ΔQ kW	α kW/m ² K	Stream name	T_{in} K	T_{out} K	ΔQ kW	α kW/m ² K
Process					Process					Process				
H1	360	320	10	1	H1	408	312	-1186	1	H1	-10.7	-10.7	-400.70	1
H2	320	250	10	1	H2	375	312	-466	1	H2	-28.9	-28.9	-823.38	1
C1	260	310	15	1	H3	375	312	-387	1	H3	51.5	51.5	-4285.30	1
C2	300	360	10	1	H4	375	312	-380	1	C1	67.9	67.9	870.83	1
					H5	375	290	-572	1	C2	-3	-3	758.94	1
					H6	269	260	-20	1	C3	62.5	62.5	4229.65	1
					H7	168	158	-157	1					
					H8	258	256.8	-381	1					
					H9	313	313	-224	1					
					H10	307	307	-141	1					
					H11	234	234	-1081	1					
					H12	290	230	-451	1					
					C1	393	440	111	1					
					C2	277	302	174	1					
					C3	158	311	208	1					
					C4	346	360	516	1					
					C5	436	498	448	1					
					C6	315	358	133	1					
					C7	252	256	1120	1					
					C8	247	298	96	1					
Utilities					Utilities					Utilities				
Water for cooling	300	310		0.56	Cooling water for cooling	297.1	300		0.56	Cooling water for cooling	295	300		0.56
Water for heating*	300	290		0.56	Cooling water for heating*	297.1	294.2		0.56	Cooling water for heating*	295	290		0.56
Steam	440	440		0.56	Steam LP	411	411		1	Steam	138	13882		1

Table 10: Benchmark cases data.

Description	Symbols	E2				Ethylene				Cold Tray			
		Data	Unit	Reference	min(HPS)	Data	Unit	Reference	min(HPS)	Data	Unit	Reference	min(HPS)
Master level													
Objective function	f_{master}^{obj}	{COPEX, CCAPEX}								Table 6			
Heat exchanger investment cost function	C^{HEN}	0											
Heat exchanger investment cost function	C^{COMP}	as slave								Table 6			
Variables													
Saturation temperature	T_1	{300, 300.5, ..., 313}	K	313	312.5	{310, 310.5, ..., 310}	K	310, ammonia	310, ammonia	{333, 333.5, ..., 353}	K	-	344
	T_2	{290, 290.5, ..., 310}	K	300	298.5	{250, 250.5, ..., 290}	K	307, r22	265.5, ammonia	{323, 323.5, ..., 353}	K	-	338.5
	T_3	{280, 280.5, ..., 300}	K	288	283	{230, 230.5, ..., 280}	K	297, ammonia	246, ammonia	{313, 313.5, ..., 343}	K	-	331
	T_4	{265, 265.5, ..., 285}	K	277	272	{220, 220.5, ..., 260}	K	266, r22	234, ethane	{303, 303.5, ..., 333}	K	-	321.5
	T_5	{250, 250.5, ..., 270}	K	254	254	{200, 200.5, ..., 240}	K	256, r22	224, ammonia	{293, 293.5, ..., 323}	K	303, r22, ammonia	302
	T_6	{245, 245.5, ..., 265}	K	247	248	{190, 190.5, ..., 230}	K	256.8, propylene	205, ethane	{283, 283.5, ..., 313}	K	274, r22	298
	T_7	240	K	240	240	{170, 170.5, ..., 210}	K	246.8, r22	189, ethane	{273, 273.5, ..., 303}	K	-	273
	T_8					{160, 160.5, ..., 200}	K	234, ethane	180.5, ethane	{253, 253.5, ..., 283}	K	259.5, ammonia	259.5
	T_9					{150, 150.5, ..., 190}	K	224, propylene	172, ethane	{243, 243.5, ..., 273}	K		257
	T_{10}					148	K	ethane	ethane	241.3	K	r22	
Subcooling temperature difference	$\Delta T_{i,SC}$					0	K			0	K		
	$\Delta T_{1,SC}$	{0, 1, ..., 20}	K	0	14								
	$\Delta T_{2,SC}$	{0, 1, ..., 20}	K	0	15								
	$\Delta T_{3,SC}$	{0, 1, ..., 15}	K	0	0								
	$\Delta T_{4,SC}$	{0, 1, ..., 15}	K	0	2								
	$\Delta T_{5,SC}$	{0, 1, ..., 5}	K	0	0								
	$\Delta T_{6,SC}$	{0, 1, ..., 5}	K	0	0								
Gas-cooling temperature difference	$\Delta T_{i,DSH}$	$T_{i-1} - T_i$	K	0	as shown	0	K			0	K		
Preheating temperature difference	$\Delta T_{i,PRE}$	0	K	0	0	0	K			0	K		
Fluid set	F	{ammonia}		ammonia	ammonia	{ammonia, propylene, r22, r13, ethane, ethylene}				{ammonia, r12, r22}			ammonia
Weighting factor	ξ	[0, 1]	-	0.5	0.47	[0, 1]	-	0.5	0.87	[0, 1]	-	0.5	0.74
Slave level													
Objective function	f_{slave}^{obj}	$wTAC$	\$/y			$wTAC$	\$/y			$wTAC$	\$/y		
Parameters taken from [23]						Parameters taken from [25]				Parameters taken from [31]			
Compressor isentropic efficiency	$\eta_{isentropic}$	1	-			1	-			1	-		
Minimum temperature difference	ΔT_{min}	10	K			10	K			2.78	K		
Set of periods	P	{1}	-			{1}	-			{1}	-		
Operating time of period	Δt_1	1	y			1	y			1	y		
Occurence of period	occ_1	1	1/y			1	1/y			1	1/y		
Maximum compression ratio	CP^{max}					10	bar/bar						
Maximum number of compressors	n^{max}					5	-			5	-		
Opex													
Steam production	OP_2^{steam}	50.91	\$/kW/y			0	\$/kW/y			56.2866	\$/kW/y		
Electricity grid	OP_2^{grid}	608.33	\$/kW/y			336	\$/kW/y			420	\$/kW/y		
Cooling water	OP_2^{cw}	15.97	\$/kW/y			6.011	\$/kW/y			6.011	\$/kW/y		
Capex													
Compressor cost	IV_1^{comp}	2824.8	\$/y			0.15 · 3,787.4	\$/y			0.15 · 3,787.4	\$/y		
	IV_2^{comp}	831.67	\$/kW/y			0.15 · 1,573	\$/kW/y			0.15 · 1,573	\$/kW/y		
Heat exchanger cost parameters	a,b	500, 0.8	\$/ -			500, 0.8	\$/ -			500, 0.8	\$/ -		
	U	1	kW/m²K			1	kW/m²K			1	kW/m²K		
	A	1	m²			1	m²			1	m²		
	Q^{min}	7	kW			100	kW			7	kW		

B.2 Extended case *E2*

The thermal streams considered in this case are depicted in Table 9(a). Figure 14a shows the parallel coordinates information generated with the tool from Kermani et al. [72]. The GWP of most selected Hydrofluorocarbonss (HFCs) (r407c, r404a, r410a, r507a) is above 1500 [79] compared to hydrogen sulfide and natural refrigerants (ammonia (r717), propane (r290), propylene (r1270)) with GWP of below 10 [79, 80] and lower-impact HFCs such as r161 (12 [81]) and r41 (97 [82]). The objective functions, variables, boundary conditions, and input data to the extended case *E2* are displayed in Table 11. Figure 14b depicts the temperature entropy diagram of the optimized HPS solution. Figure 15a displays the integrated composite curves of the extended case. In the reference case, cooling water is required to cool the highest condenser level which is increased compared to the benchmark case due to the lower compressor isentropic efficiency. Since the cooling water outlet temperature is above the condenser temperature, part of it needs to be heated by the hot utility. Figure 15b presents a flowsheet of the minimum TAC case. The two HEN design of the reference and optimized case is shown in Figure 16. It has to be noted that the HPS solution requires one more heat exchangers which is mildly penalized by the HEN cost function thereby being outweighed by the benefits of the reduced opex.

Figure 14: Set of selected fluids considered during multi-objective optimization.

(a) Integrated composite curves of optimized and reference case.

(b) Flowsheet of optimum case.

Figure 15: Extended case *E2* minimum TAC solution.

(a) HEN design of extended reference case *E2*.

(b) HEN design of extended case *E2* minimum TAC solution.

Figure 16: HEN design with Aspen Energy Analyzer [83].

Table 11: Optimization problem description: extended case *E2*.

Description	Symbols	Data	Unit	Reference	min(HPS)
<i>Master level</i>					
Objective function	f_{master}^{obj}	$\{C^{OPEX}, C^{CAPEX}\}$	\$/y	56 005	49 944,
Heat exchanger cost function (estimation)	C^{HEN}	C^{HEN} Table 3	\$/y	132 608	121 840
HEN design			\$/y	58 800	57 800
	c_1 fitted from [23]	0	\$	52 800	53 600
	c_2 fitted from [23]	500	\$/y		
	c_3 fitted from [23]	0.8	-		
Variables					
Saturation temperature	$T_i = T_{i+1} + \Delta T_i$				
	ΔT_1	{5, 5.5, ..., 40}	K	13	9
	ΔT_2	{5, 5.5, ..., 40}	K	12	11.5
	ΔT_3	{5, 5.5, ..., 40}	K	11	13
	ΔT_4	{5, 5.5, ..., 40}	K	23	25
	ΔT_5	{5, 5.5, ..., 40}	K	7	8.5
	ΔT_6	{5, 5.5, ..., 40}	K	7	7.5
	T_7	240	K	240	240
Subcooling temperature difference					
	$\Delta T_{1,SC}$	{0, 1, ..., 20}	K	0	12
	$\Delta T_{2,SC}$	{0, 1, ..., 20}	K	0	0
	$\Delta T_{3,SC}$	{0, 1, ..., 15}	K	0	0
	$\Delta T_{4,SC}$	{0, 1, ..., 15}	K	0	11
	$\Delta T_{5,SC}$	{0, 1, ..., 10}	K	0	0
	$\Delta T_{6,SC}$	{0, 1, ..., 10}	K	0	0
De-superheating temperature difference	$\Delta T_{i,DSH}$	$T_{i-1} - T_i$	K	0	as indicated
Preheating temperature difference	$\Delta T_{i,PRE}$	0	K	0	0
Fluid set	F	{ammonia,r161,h2s,propane,propylene, r407c,r404a,r410a,r507a,r41}		ammonia	propane
Weighting factor	ξ	[0, 1]	-	0.5	0.58
<i>Slave level</i>					
Objective function	f_{slave}^{obj}	$wTAC$	\$/y		
<i>Parameters</i>					
Compressor isentropic efficiency	$\eta_{isentropic}$	0.7	-		
Minimum temperature difference	ΔT_{min}	10	K		
Set of periods	P	{1}	-		
Operating time of period	Δt_1	1	y		
Occurence of period	occ_1	1	1/y		
Maximum compression ratio	CP^{max}	8	bar/bar		
<i>Opex</i>					
Steam production	OP_2^{steam}	50.91	\$/kW/y		
Electricity grid	OP_2^{grid}	608.33	\$/kW/y		
Cooling water	OP_2^{cw}	15.97	\$/kW/y		
<i>Capex</i>					
Compressor cost	IV_1^{comp}	2824.8	\$/y		
	IV_2^{comp}	831.67	\$/kW/y		

C Slave level - mathematical fomulation

C.1 Utility targeting constraints

The general utility targeting problem is derived based on the work by Maréchal and Kalitventzeff [68].

Heat cascade The second law of thermodynamics states that heat can only flow from a source at higher temperature to a sink at colder temperature and is expressed in the heat cascade constraints in Equation 13-14. These constraints ensure maximum heat recovery in the system.

$$\sum_{w \in \mathbf{W}} f_p^w \cdot \dot{Q}_{p,k}^w + \sum_{s \in \mathbf{S}} \dot{Q}_{p,k}^s + \dot{R}_{p,k+1} - \dot{R}_{p,k} = 0 \quad \forall p \in \mathbf{P}, k \in \mathbf{K} \quad (13)$$

$$\dot{R}_{p,k} \geq 0, \quad \dot{R}_{p,1} = 0, \quad \dot{R}_{p,n_k+1} = 0 \quad \forall p \in \mathbf{P}, k \in \mathbf{K} \quad (14)$$

Where

$\mathbf{P}$	is the set of time periods $\{1,2,3, \dots, n_p\}$
$\mathbf{K}$	set of temperature intervals $\{1,2,3, \dots, n_k\}$
$\mathbf{S}$	set of process streams
f_p^w	continuous variable for sizing technology w during period p
y_p^w	binary variable related to existence of technology w during p
f^w	maximum size of technology w
y^w	overall existence of technology w
$\dot{Q}_{p,k}^w$	[kW] reference heat release or demand of a technology w during period p in the temperature interval k
$\dot{Q}_{p,k}^s$	[kW] heat release or demand of process stream s during period p in the temperature interval k
$\dot{R}_{p,k}$	[kW] residual heat of temperature interval $k - 1$ that is cascaded to interval k during period p

Sizing constraints The dimensions of the utility technologies are constrained between specified boundaries as depicted in Equation 15.

$$f^w - f_p^w \geq 0, \quad y^w - y_p^w \geq 0, \quad f^{w,\min} \cdot y_p^w \leq f_p^w \leq f^{w,\max} \cdot y_p^w \quad \forall p \in \mathbf{P} \quad (15)$$

Electricity balance The electricity balance in Equation 16 is closed by considering the electricity input and output of all utility technologies w .

$$\sum_{w \in \mathbf{W}} f_p^w \cdot \dot{E}^w = 0 \quad \forall p \in \mathbf{P} \quad (16)$$

Where

$\dot{E}^w$	[kW] reference electricity consumption (positive) or production (negative) of a technology w during period p
-------------	--

Natural gas balance The natural gas balance in Equation 17 is closed by considering the natural gas input and output of all utility technologies w .

$$\sum_{w \in \mathbf{W}} f_p^w \cdot \dot{Q}^w = 0 \quad \forall p \in \mathbf{P} \quad (17)$$

Where

$\dot{Q}^w$	[kW] reference natural gas input (positive) or output (negative) of a technology w during period p
-------------	--

C.2 Heat pump superstructure

C.2.1 HPS parameters entering the utility targeting

In the following formulations, the heat and electricity consumption or production of the heat pump utilities is described for a reference mass flow rate which is to say, a fixed size. These parameters enter into the utility targeting constraints Equation 13-15 where they are multiplied with sizing factors.

The heat release in a condenser at saturation temperature T_i of heat pump g for a reference flow rate $\dot{m}_{\text{ref}}$ [kg/s] is composed of three parts: de-superheating from the preheating level $T_{i,\text{PRE}}$ [K], condensation at the saturation temperature, and subcooling between saturation and subcooling temperature $T_{i,\text{SC}}$ [K]. As such, the heat release in a condenser is defined by Equation 18.

$$\begin{aligned}\dot{Q}^{g, \text{cond}, i} &= -\dot{m}_{\text{ref}} \cdot \left([h_{\text{PRE}}(T_i) - h_V(T_i)]_{T_i}^{T_{i,\text{PRE}}} + [h_V(T_i) - h_L(T_i)]_{T_i} + [h_L(T_i) - h_{\text{SC}}(T_i)]_{T_i}^{T_{i,\text{SC}}} \right) \\ &= -\dot{m}_{\text{ref}} \cdot (\Delta h_{\text{cond}}(T_i) + \Delta h_{\text{SC}}(T_i) + \Delta h_{\text{PRE}}(T_i))\end{aligned}\quad (18)$$

Where $T_{i,\text{PRE}}$ is the preheating temperature before compression [K], h_{PRE} is the enthalpy before compression [kJ/kg], h_V [kJ/kg] is the vapor and h_L [kJ/kg] is the liquid saturation enthalpy.

The heat consumption of an evaporator at saturation temperature T_i of heat pump g is composed of two parts: evaporation at the saturation temperature and superheating between saturation and preheating temperature. As such, the heat consumption in an evaporator is defined by Equation 19.

$$\begin{aligned}\dot{Q}^{g, \text{evap}, i} &= \dot{m}_{\text{ref}} \cdot \left([h_V(T_i) - h_L(T_i)]_{T_i} + [h_{\text{PRE}}(T_i) - h_V(T_i)]_{T_i}^{T_{i,\text{PRE}}} \right) \\ &= \dot{m}_{\text{ref}} \cdot (\Delta h_{\text{evap}}(T_i) + \Delta h_{\text{PRE}}(T_i))\end{aligned}\quad (19)$$

The liquid side of the presaturator also needs to be cooled down to the subcooling temperature which is formulated similarly and shown by Equation 20.

$$\dot{Q}^{g, \text{presat}, i} = \dot{m}_{\text{ref}} \cdot [h_L(T_i) - h_{\text{SC}}(T_i)]_{T_i}^{T_{i,\text{SC}}} \quad (20)$$

Gas-cooling to the compressor inlet temperature from the superheated vapor at the compressor outlet can be achieved by mixing in the presaturator or in a heat exchanger as described in Equation 21.

$$\dot{Q}^{g, \text{gas-cool}, i} = \dot{m}_{\text{ref}} \cdot [h_{\text{SH}}(T_i) - h_{\text{PRE}}(T_i)]_{T_{i,\text{PRE}}}^{T_{i,\text{SH}}} \quad (21)$$

Where h_{SH} is the enthalpy to which the superheated compressor outlets are mixed [kJ/kg], and $T_{i,\text{SH}}$ is the respective temperature [K].

The electricity consumption of a compressor depends on the isentropic efficiency and the enthalpies of both pressure levels, formulated as Equation 22.

$$\dot{E}^{g, \text{comp}, i \rightarrow j} = \dot{m}_{\text{ref}} \cdot \left[\frac{h_{\text{isentropic}}(T_j) - h_V(T_i)}{\eta_{\text{isentropic}}} \right] \quad (22)$$

Where $h_{\text{isentropic}}(T_j)$ [kJ/kg] is the isentropic enthalpy after compression from saturated vapor at temperature level T_i to (saturation) temperature level T_j , and $\eta_{\text{isentropic}}$ is the isentropic compressor efficiency [-]. The HPS stream properties are depicted in Table 12.

Table 12: Data of streams of the HPS.

Unit	Name	T_{in} K	T_{out} K	$ \Delta Q $ kJ/kg	α kW/m ² K
Condenser	condensation	T_i	T_i	$h_V(T_i) - h_L(T_i)$	1.6
	sub-cooling	T_i	$T_{i,SC}$	$h_L(T_i) - h_{SC}(T_i)$	0.56
	de-superheating	$T_{i,PRE}$	T_i	$h_{PRE}(T_i) - h_V(T_i)$	0.06
Evaporator	evaporation	T_i	T_i	$h_V(T_i) - h_L(T_i)$	3.6
	preheating	T_i	$T_{i,PRE}$	$\Delta h_{PRE}(T_i)$	0.06
Gas-cooler	gas-cooling	$T_{i,SH}$	$T_{i,PRE}$	$h_{SH}(T_i) - h_{PRE}(T_i)$	0.06
Presaturator	sub-cooling	T_i	$T_{i,SC}$	$h_L(T_i) - h_{SC}(T_i)$	0.56

Figure 17: Temperature-entropy diagram with mass and energy balances of the HPS.

C.2.2 Heat pump specific constraints

In the following the heat pump specific linear equations at the slave level are introduced.

Liquid mass balance The liquid mass balance at temperature level i can be at saturated or sub-cooled conditions depending whether $\Delta T_{i,SC} > 0$ (sub-cooled) or $\Delta T_{i,SC} = 0$ (saturated). It is shown in Equation 23 of heat pump g and is composed of:

- the positive contribution from the potential condenser at level i
- the negative contribution from the potential evaporator at level i
- the positive contribution of the liquid fraction of all valves in combination with presaturators that end at level i
- the negative contribution from all valves that exit from level i
- the negative contribution of the fraction of liquid that may be used to de-superheat the compressor outlets (mix) at level i

$$f_p^{g, \text{cond } i} - f_p^{g, \text{evap } i} + \sum_{j=1}^{i-1} \left(1 - x_V^{g, j \rightarrow i}\right) \cdot f_p^{g, \text{presat } j \rightarrow i} - \sum_{k=i+1}^{n_l} f_p^{g, \text{presat } i \rightarrow k} - f_p^{\text{mix } i} = 0$$

$$\forall i \in \mathbf{L}, g \in \mathbf{G}, p \in \mathbf{P} \quad (23)$$

Where

$\mathbf{G}$	set of heat pumps g consisting of one fluid d
$\mathbf{L}$	set of heat pump saturation temperature levels $\{1, 2, 3, \dots, n_l\}$
$f_p^{g, \text{cond } i}$	condenser sizing factor of heat pump g (containing fluid f) during period p
$f_p^{g, \text{evap } i}$	evaporator sizing factor of heat pump g during period p
$f_p^{g, \text{mix } i}$	mixer sizing factor of heat pump g during period p
$f_p^{g, \text{presat } j \rightarrow i}$	presaturator after expansion from temperature level $j \rightarrow i$ sizing factor of heat pump g during period p
$x_V^{g, j \rightarrow i}$	vapor fraction after expansion from temperature level $j \rightarrow i$ of heat pump g
h_{SC}^g	[kJ/kg] enthalpy at subcooled or saturated temperature level $T_{i,SC} = T_i - \Delta T_{i,SC}$ of heat pump g

Liquid energy balance The liquid energy balance in Equation 24 is trivial because all streams enter and exit at the same state of matter and temperature.

$$\left(f_p^{g, \text{cond } i} - f_p^{g, \text{evap } i} + \sum_{j=1}^{i-1} \left(1 - x_V^{g, j \rightarrow i} \right) \cdot f_p^{g, \text{presat } j \rightarrow i} - \sum_{k=i+1}^{n_l} f_p^{g, \text{presat } i \rightarrow k} - f_p^{g, \text{mix } i} \right) \cdot h_{\text{SC}}^{g, i} = 0$$

$$\forall i \in \mathbf{L}, g \in \mathbf{G}, p \in \mathbf{P} \quad (24)$$

Vapor mass balance The vapor mass balance at temperature level i can be at saturated or superheated conditions depending whether $\Delta T_{i, \text{PRE}} > 0$ (superheated) or $\Delta T_{i, \text{PRE}} = 0$ (saturated). It is shown in Equation 25 of heat pump g and is composed of:

- the positive contribution from the potential evaporator at level i
- the negative contribution from the potential condenser at level i
- the negative contribution from all compressors that exit from level i
- the potential incoming mass flow related to the potential gas-cooling heat exchanger unit from the superheated mass balance at level i
- the potential positive contribution from a de-superheating through mixing unit at level i

$$f_p^{g, \text{evap } i} - f_p^{g, \text{cond } i} - \sum_{j=1}^{i-1} f_p^{g, \text{comp } i \rightarrow j} + f_p^{g, \text{gas-cool } i} + f_p^{g, \text{de-sup mix } i} = 0$$

$$\forall i \in \mathbf{L}, g \in \mathbf{G}, p \in \mathbf{P} \quad (25)$$

Where

$f_p^{g, \text{comp } j \rightarrow i}$	sizing factor of compressor from level $j \rightarrow i$	sizing factor of heat pump g during period p
$f_p^{g, \text{de-sup mix } i}$	sizing factor of the de-superheating through mixing unit of heat pump g during period p	
$f_p^{g, \text{gas-cool } i}$	sizing factor of the gas-cooling heat exchanger of heat pump g during period p	

The energy balance in this case is trivial, since all streams enter and exist at $h_{\text{PRE}}^{g, i}$ [kJ/kg], the enthalpy at preheated or saturated temperature level $T_{i, \text{PRE}} = T_i + \Delta T_{i, \text{PRE}}$ of heat pump g . This balance is not displayed here.

Superheated vapor mass balance The superheated vapor mass balance at temperature level i is conducted at superheated conditions $\Delta T_{i, \text{SH}} = T_i + \Delta T_{i, \text{SH}}$. It is shown in Equation 26 of heat pump g and is composed of:

- the positive contributions of each compressor entering level i
- the positive contribution of the vapor fraction of all valves in combination with presaturators that end at level i
- the negative contribution from the gas-cooling and de-superheating through mixing units at level i
- and the positive contribution from the liquid mixing unit at level i

$$\sum_{k=i+1}^{n_l} f_p^{g, \text{comp } k \rightarrow i} + \sum_{j=1}^{i-1} x_V^{g, j \rightarrow i} \cdot f_p^{g, \text{presat } j \rightarrow i} - f_p^{g, \text{gas-cool } i} - f_p^{g, \text{de-sup mix } i} + f_p^{g, \text{mix } i} = 0$$

$$\forall i \in \mathbf{L}, g \in \mathbf{G}, p \in \mathbf{P} \quad (26)$$

Superheated vapor energy balance The energy balance given in Equation 27 ensures that regardless of which compressor is active, the starting point for de-superheating is always fixed. This constraint ensures energy conservation and linearity in the problem formulation.

$$\sum_{k=i+1}^{n_l} f_p^{g, \text{comp } k \rightarrow i} \cdot h_{\text{out}}^{g, \text{comp } k \rightarrow i} - f_p^{g, \text{gas-cool } i} \cdot h_{\text{SH}}^{g, i} - f_p^{g, \text{de-sup mix } i} \cdot h_{\text{PRE}}^{g, i} + f_p^{g, \text{mix } i} \cdot h_{\text{L}}^{g, i} = 0$$

$$\forall i \in \mathbf{L}, g \in \mathbf{G}, p \in \mathbf{P} \quad (27)$$

Where

$h_{\text{PRE}}^{g,i}$	[kJ/kg] enthalpy at preheated or saturated temperature level $T_{i,\text{PRE}} = T_i + \Delta T_{i,\text{PRE}}$ of heat pump g
$h_{\text{SH}}^{g,i}$	[kJ/kg] superheated vapor enthalpy at point $T_{i,\text{SH}} = T_i + \Delta T_{i,\text{SH}}$
$h_{\text{out}}^{g,\text{comp } k \rightarrow i}$	[kJ/kg] outlet enthalpy of compressor from level k to i